



RESIDENTIAL TRANQUILITY® 24 (SZ) VERSATILE TWO-STAGE SERIES PRODUCT CATALOG

Part#: RP3000 | Revised: May 2, 2025

Models: SZ 024-060
60Hz - R-454B



Table of Contents

Models:
SZ
024-060

3	Introduction	34	High Head and Standard Variable Pump Performance
5	Features, Options, and Accessories	35	Antifreeze Correction Table
6	iGate 2 Communicating Controls Powered by DXM2.5 Advanced Communicating Controls	37	Water Pressure Drop Adder for Options: Correction Tables
7	iGate 2 Communicating (AWC) Thermostat	38	Physical Data
8	myUplink: Web and Mobile Interface	39	Horizontal Dimensional Data
9	vFlow Internal Variable Water Flow Control	40	Horizontal Service Access
11	iGate 2 Smart Tank	42	Vertical Service Access
12	Selection Procedure	43	Dimensional Data
14	Model Nomenclature	45	Electric Heater Knockouts
15	Performance Data: AHRI/ASHRAE/ISO 13256-1	46	Corner Weights
17	Performance Data: Selection Notes	47	Minimum Installation Area
18	Performance Data	48	Accessories & Options
30	Blower Performance: CV EC Standard Unit	49	Warranty
31	Electrical Data: CV EC Blower Motor	50	Revision History
32	Correction Tables		
33	Full Load Performance: Correction Tables		

THE TRANQUILITY® 24 (SZ) VERSATILE TWO-STAGE SERIES

The Tranquility 24 (SZ) Versatile Two-Stage Series showcases superb efficiency ratings, quiet operation, and application flexibility that is synonymous with the ClimateMaster Tranquility family. The Tranquility SZ surpasses ASHRAE 90.1 efficiency standards and utilizes R-454B low Global Warming Potential (GWP) refrigerant, setting a high standard for eco-friendly performance. The SZ is Energy Star certified due to its innovative and environmentally conscious design.

Available in sizes 2 tons (7.0 kW) through 5 tons (17.6 kW) with multiple cabinet options (vertical upflow and horizontal) the Tranquility SZ offers a wide range of units for most any installation. The Tranquility SZ has an extended range refrigerant circuit, capable of ground loop (geothermal) applications as well as open loop applications. Some of the features of the innovative Tranquility SZ series include: ultra-efficient Two-Stage unloading scroll compressor, EC variable fan motor, microprocessor controls, black powder-coated galvanized-steel cabinet construction, corrosive-resistant stainless-steel drain pan, and acoustic-type fiber insulation are just some of the features of the innovative Tranquility SZ Series.

Recent EPA mandates require an industry transition to low-GWP refrigerants, such as R-454B which is a gas that is classified as having low-toxicity, low-flammability rating. Due to these characteristics, R-454B systems charged with over 62 ounces of refrigerant must contain an integrated Refrigerant Detection System (RDS). In the unlikely event of a system-refrigerant leak, the RDS shuts down compressor operation and runs the unit blower motor to disperse any concentration of leaked refrigerant in compliance with UL 60335-2-40 safety standards. For Tranquility SZ products, only the 5 ton size (060) is required to have the RDS and the feature is optional on all other sizes.

ClimateMaster's exclusive double isolation compressor mounting system makes the Tranquility SZ one of the quietest units on the market. Compressors are mounted using specially engineered sound tested EPDM grommets to a heavy gauge mounting plate, which is then isolated from the cabinet base with EPDM grommets to minimize vibration transmission and maximize sound attenuation. Multiple removable access panels and an easily accessible control box make installation and maintenance user friendly. Options such as coated air coil, internal variable speed pump, modulating water valve, and high efficiency MERV rated air filters allow for customizable design solutions.

iGate® 2 technology provides technicians an interface into the operation of the system in real time without the need for hard tooling. On-board advanced controls communicate the key operating system temperatures allowing technicians to startup, commission, and service equipment remotely by smart phone or website interface. Communication can also be established at the unit via an AWC Thermostat or Wireless Service Tool. Not only does iGate 2 monitor current performance, it also allows the functionality to make system adjustments and captures operating conditions at time of fault. The data is presented in a user-friendly format, enhancing the overall usability of the experience.

vFlow® is ClimateMaster's variable water flow technology. It represents a major advancement in water flow system management efficiency. vFlow not only builds major water circulation components into the unit for a clean installation, it also intelligently varies water flow to minimize pump energy consumption and improve system reliability.

The heart of vFlow is either a variable-speed pump or modulating water valve intelligently controlled with DXM2.5 Advanced Communicating Controls. Water flow is automatically varied based on changes in unit capacity level (stage) and source water temperature to maintain optimum system performance. vFlow allows the use of direct return piping, while eliminating external two-way valves and automatic flow regulators, making vFlow systems inherently self-balancing.

vFlow systems provide reduced water pumping power compared to traditional fixed-speed pumping systems. They also protect the unit against extreme operating conditions, thus extending the life of the compressor and air coil. Since vFlow is built inside the unit, it also saves on installation time and makes for a very clean and compact installation. The Tranquility SZ Series water-source heat pumps are designed to meet the challenges of today's HVAC demands with one of the most innovative products available on the market.

FEATURES

- Sizes 024 (2 ton, 7 kW) through 060 (5 tons, 17.6 kW)
- Exceeds ASHRAE 90.1 efficiency standards
- Environmentally-friendly R-454B low-GWP refrigerant
- Refrigerant Detection System (RDS) (mandatory on size 060, optional feature for sizes 024-048)
- Intelligent variable-speed Constant Volume (CV) EC blower motors for precise airflow control and soft-start feature
- Part-load operation significantly lowers annual operating costs
- Galvanized-steel cabinet construction with matte-black polyester powder-coated finish
- Sound-absorbing glass-fiber insulation
- Unique double-isolation compressor mounting with vibration isolation for quieter operation
- Insulated divider and separate compressor/air-handler compartments
- TXV metering device
- Field-convertible supply-air arrangement (horizontal configurations only)
- Unit Performance Sentinel performance-monitoring system
- Eight standard safety features
- Easy-to-clean rust-prohibitive stainless-steel drain pans
- DXM2.5 Advanced Communicating Controls:
 - Multiple communication pathways for unit access and diagnosis:
 - Cloud-based remote monitoring via iGate 2 Communicating (AWC) Thermostat
 - Connect directly to the system with the Wireless Service Tool
 - Provides real-time unit operating conditions
 - Reduces startup, commissioning, and service time by providing key system temperatures electronically
 - Captures operating conditions in the event of a safety shutdown
- Anti-short cycle and over-/under-voltage protection
- Easy-access control box
- High-pressure, loss-of-charge, and condensate-overflow protection
- LED fault and status indication at controller
- Extended-range insulation for geothermal applications
- Tin-plated air coils for added protection from formicary corrosion
- Return-air filter frames and 1-inch Merv 8 filter

OPTIONS

- Corrosion-resistant cupro-nickel water-heat exchanger
- Domestic Hot Water Generator (HWG)
- vFlow unit-integrated variable-speed water pump
- vFlow unit-integrated modulating water valve for maximum water-flow control (replaces traditional motorized water valve and autoflow regulator)
- Factory-installed compressor soft starter to reduce inrush current for more efficient startups
- Integrated power disconnect


ACCESSORIES

- iGate 2 Communicating (AWC) Thermostat with color touchscreen
- iGate 2 Smart Tank
- Wide variety of thermostat options to meet your application needs
- Auxiliary electric heaters

iGate 2 Communicating Controls Powered by DXM2.5 Advanced Communicating Controls

Models:
SZ
024-060

iGATE 2 COMMUNICATION – CLOUD CONNECTED, WEB-ENABLED INFORMATION GATEWAY TO MONITOR, CONTROL, AND DIAGNOSE YOUR SYSTEM



The Tranquility SZ is equipped with industry-first, iGate 2 communication information gateway that allows users to interact with their water-source system in easy to read clear language AND delivers improved reliability and efficiency by precisely

controlling smart components.

Monitor/Configure: From the myUplink PRO website, mobile app, AWC Thermostat, or Wireless Service Tool, installers can configure the following: airflow, unit family, size, accessory configuration, and demand reduction (optional, to limit unit operation during peak times). Users can look up the current system status: temperature sensor readings and operational status of the blower.


Precise Control: The DXM2.5 enables intelligent, two-way communication between the DXM2.5 and smart components like the AWC Thermostat, Wireless Service Tool, and constant volume CV EC blower motor. DXM2.5 Advanced Communicating Controls uses information received from the smart components and temperature sensors to precisely control operation of the variable speed CV EC fan to deliver higher efficiency, reliability and increased comfort.

Diagnostics: iGate 2 takes diagnosing water-source heat pump units to a next level of simplicity, by providing a dashboard of system and fault information, in clear language, on the AWC Thermostat, Wireless Service Tool, and the web portal/mobile app on the internet.

iGate 2 Service Warnings notify the homeowner and contractor of a fault and displays fault descriptions by app notifications and email with possible causes. Additionally, the current system status can be viewed graphically on the web portal and mobile app.

In iGate 2 Service Mode, the service personnel can access fault description, possible causes and most importantly, the conditions (temp, flow, i/o conditions, configuration) at the time of the fault. Manual Operation mode allows the service personnel to manually command operation for any of the thermostat outputs, blower speed, to help troubleshoot specific components. This operation can either be conducted at the unit with a Wireless Service Tool or remotely with mobile app/website when AWC Thermostat controls are used.

With an iGate 2 communicating system, users and contractors have a web-enabled gateway to system information never before available and exclusive to ClimateMaster products.




ClimateMaster works continually to improve its products. As a result, the design and specifications of each product at the time of order may be changed without notice and may not be as described herein. Please contact ClimateMaster's Customer Service Department at 800-299-9747 for specific information on the current design and specifications. Statements and other information contained herein are not express warranties and do not form the basis of any bargain between the parties, but are merely ClimateMaster's opinion or commendation of its products. The latest version of this document is available at www.climatemaster.com. Engineered and assembled in the USA. © ClimateMaster, Inc. All Rights Reserved 2024

iGate 2 Communicating (AWC) Thermostat

Models:
SZ
024-060

iGATE 2 COMMUNICATION – CLOUD CONNECTED, WEB-ENABLED INFORMATION GATEWAY TO MONITOR, CONTROL, AND DIAGNOSE YOUR SYSTEM



The iGate 2 Communicating (AWC) Thermostat is innovating the future of comfort technology, one building at a time. The inspired design of the touch screen interface allows you to see real-time data for the efficiency and health of your system, with early warnings for potential system faults. The cloud based information gateway allows technicians to remotely diagnose system issues before occupants even know there is a problem. Control and monitor the system in your home or business from anywhere in the world with an easy to use app on your phone.

Features with Efficiency in Mind



Touchscreen Interface

A brilliantly customizable touchscreen monitor for simple control.



Seamless Integration

Between your AWC Thermostat and comfort system.



(Mobile) Remote System Control

Control temperature and schedule from anywhere in the world.



Early Fault Warnings

Alerts the building owner and the contractor of potential system faults in the future.



Remote Diagnostics

Enable the contractor to remotely diagnose system issues, adjust system settings, and reset faults.



Real-Time Operations Data and System Schematics

Access simply via the myUplink PRO Account and web portal to view system diagrams with current operating temperatures.




Revenue Stream

HVAC professionals can offer owners service contracts with remote monitoring and diagnostic capabilities without the large expense of a building management system.



ClimateMaster works continually to improve its products. As a result, the design and specifications of each product at the time of order may be changed without notice and may not be as described herein. Please contact ClimateMaster's Customer Service Department at 800-299-9747 for specific information on the current design and specifications. Statements and other information contained herein are not express warranties and do not form the basis of any bargain between the parties, but are merely ClimateMaster's opinion or commendation of its products. The latest version of this document is available at www.climatemaster.com. Engineered and assembled in the USA. © ClimateMaster, Inc. All Rights Reserved 2024

HVAC Professional | User Experience



iGate 2 establishes a two-way link between the AWC Thermostat and the cloud, adding significant value for both residential and commercial customers. Our new thermostat works with your customers' Tranquility comfort systems to


provide the most efficient link between their system and your services. The customizable monitoring from the myUplink PRO web portal or phone app account allows for continuous system monitoring, analysis, repair recognition, and early warnings for potential system faults that are sent to you and your customer.



Benefits

- Remote login from anywhere, anytime from any internet connected device
- View system fault history with possible root causes
- Information is available for contractors to troubleshoot and diagnose systems remotely
- Secure internet connection keeps homeowner information private
- Access thermostat(s) through Android and iPhone mobile apps

Homeowner | User Experience



iGate 2 advanced unit controls enable a two-way communication link for critical system information between the unit and the cloud. From any internet connected device or smart phone, building owners can control and monitor their systems

from anywhere in the world. iGate 2 offers building owners peace of mind their systems are operating at peak performance with advanced operational performance issue notifications. HVAC professionals get notifications when systems are operating out of range. They can log in remotely to check system faults, review current operating conditions, and diagnose issues remotely. This gives the HVAC technician the upper hand when showing up to perform service, saving time which in turn, saves money.



Benefits

- Communicates personal settings and reminders through the iGate 2 communication system
- Easy-to-use, full-color, high-resolution user interface
- Sleek, intuitive control panel
- Secure internet connection keeps your information private
- Contains unit model, serial number and your HVAC professionals contact information
- System monitoring automatically contacts HVAC system providers when service is needed

vFLOW INTERNAL VARIABLE WATER FLOW

Industry-first, built-in vFlow replaces a traditionally inefficient, external component of the system (water circulation) with an ultra-high-efficient, variable speed, internal water flow system. This saves 70-80% on water circulation compared to traditional single speed pump systems. Multi-unit installations are also much simpler with vFlow systems, as the units automatically adjust water flow across the system.

vFlow is enabled by iGate 2, which facilitates intelligent communication between the thermostat, DXM2.5 Advanced Communicating Controls, sensors, and internal water pump/valve to make true variable water flow a reality.

vFLOW IS AVAILABLE IN FOUR VARIATIONS:

1. Low System Pressure Drop Modulating Valve

The high CV motorized valve is used for a multi-unit or central pumping, closed loop application.

2. High System Pressure Drop Modulating Valve

Motorized valve for higher pressure water systems such as a water well or other open loop applications. A cupro-nickel water coil is standard with this option.

3. Standard Head Variable Pump Internal Flow Controller

Multi-unit or central pumping for a closed loop application. The Internal Flow Controller includes a variable speed pump, flushing ports, 3-way flushing valves, and an expansion tank.

4. High Head Variable Pump Internal Flow Controller

Multi-unit or individual unit for a closed loop application. The Internal Flow Controller includes a variable speed pump, flushing ports, 3-way flushing valves, and an expansion tank.

vFLOW DELIVERS THREE MAIN BENEFITS:

1. Easier and quicker unit installation as the flow control is built in to the unit.
2. Superior reliability by varying the water flow to deliver more stable operation.
3. Increased cost savings by varying the flow (and pump watt consumption) to match the unit's mode of operation.

INTERNAL COMPONENTS

All Tranquility products can be installed more easily and compactly than their predecessors because vFlow components are internal to the unit. They also save installing contractors labor and time by eliminating the need for an external flow regulator or a bulky external pumping module.

VARIABLE FLOW

vFlow technology enables variable water flow through the unit, with the DXM2.5 adjusting the pump speed to maintain an installer-set loop ΔT . By controlling the water flow, the system is able to operate at its optimal capacity and efficiency. vFlow provides a lower flow rate for part load where units typically operate 80% of the time and a higher, more normal flow rate for full load operation.

Variable speed pump or motorized modulating valve delivers variable water-flow, controlled by DXM2.5, based on loop water ΔT .





ENERGY SAVINGS WITH WATER CIRCULATION CONTROL

Units with vFlow deliver greater operating cost savings by varying the water flow to match the unit's operation (ex: lower water flow when unit is in part load operation). Lowering the flow results in lower energy consumption by the water pump and cost savings in vFlow units (whether internal or external pump).

In applications using vFlow with internal variable speed electronically commuted (EC) pump, the EC pump uses fewer watts than a fixed speed (PSC) pump even at full load. The EC pump excels in energy savings in part load, saving 70-80% watts compared to fixed speed pumps (see chart). The EC pump can operate with independent flow rates for both heating and cooling operations allowing for more energy savings.

In loop applications, when the motorized modulating valve slows down the water flow during part load operation, the external pump consumes fewer watts, thus saving more energy.





iGate 2 Smart Tank Features

1. Brass temperature and pressure relief valve
2. iGate 2 Smart Tank communicates with the geothermal heat pump through DXM2.5 Advanced Communicating Controls
3. Polyethylene outer jacket is car bumper tough
4. Water temperature sensors continuously monitor water temperature and communicate this information to the heat pump. When water temperature falls below preference settings, the heat pump generates hot water.

iGate 2 Smart Tank Features

5. Inlet port for incoming water from the heat pump
6. Full port ball valve for fast water drainage
7. Seamless polybutene tank is impervious to rust
8. 2.5-inch insulation for reduced standby heat loss.
9. Titanium heating elements for longevitiy and superior corrosion resistance
10. Bowl-shaped bottom for more complete sediment drainage

Selection Procedure

Models:
SZ
024-060

Reference Calculations

Heating	Cooling
$LWT = EWT - \frac{HE}{GPM \times \text{Constant}}$ $LAT = EAT + \frac{HC}{CFM \times 1.08}$	$LWT = EWT + \frac{HR}{GPM \times \text{Constant}} \quad LC = TC - SC$ $LAT (DB) = EAT (DB) - \frac{SC}{CFM \times 1.08} \quad S/T = \frac{SC}{TC}$

Constant = 500 for water, 485 for antifreeze

Conversion Table - to convert inch-pound (English) to S-I (Metric)

Airflow	Water Flow	External Static Pressure	Water Pressure Drop
Airflow (L/s) = CFM x 0.472	Water Flow (L/s) = GPM x 0.0631	ESP (Pa) = ESP (in of wg) x 249	PD (kPa) = PD (ft of hd) x 2.99

Legend and Glossary of Abbreviations

Abbreviations	Descriptions
Btuh	Btu (British Thermal Unit) per hour
BMS	Building Management System
CDT	Compressor discharge temperature
CFM	Airflow, cubic feet per minute
COP	Coefficient of performance = Btuh output/Btuh input
CT EC	Electronically commutated constant torque blower motor
CV EC	Electronically commutated constant volume blower motor
DB	Dry bulb temperature, °F
DT	Delta T
EAT	Entering air temperature
EER	Energy efficient ratio = Btuh output/Watt input
ESP	External static pressure, inches w.g.
EWT	Entering water temperature
FPT	Female pipe thread
GPM	Water flow in U.S., gallons per minute
HC	Air heating capacity, Btuh
HE	Total heat of extraction, Btuh
HGRH	Hot Gas Reheat

Abbreviations	Descriptions
HR	Total heat of rejection, Btuh
HWG	Hot water generator (desuperheater) capacity, MBtuh
kW	Total power unit input, kilowatts
LAT	Leaving air temperature, °F
LC	Latent cooling capacity, Btuh
LOC	Loss of charge
LWT	Leaving water temperature, °F
MBtuh	1,000 Btu per hour
MPT	Male pipe thread
MWV	Motorized water valve
PSC	Permanent split capacitor
RDS	Refrigerant Detection System
SC	Sensible cooling capacity, Btuh
S/T	Sensible to total cooling ratio
TC	Total cooling capacity, Btuh
TD or delta T	Temperature differential
VFD	Variable frequency drive
WB	Wet bulb temperature, °F
WPD	Waterside pressure drop, psi or feet of head
WSE	Waterside economizer

ClimateMaster works continually to improve its products. As a result, the design and specifications of each product at the time of order may be changed without notice and may not be as described herein. Please contact ClimateMaster's Customer Service Department at 800-299-9747 for specific information on the current design and specifications. Statements and other information contained herein are not express warranties and do not form the basis of any bargain between the parties, but are merely ClimateMaster's opinion or commendation of its products. The latest version of this document is available at www.climatemaster.com. Engineered and assembled in the USA. © ClimateMaster, Inc. All Rights Reserved 2024

USE THE FOLLOWING SELECTION STEPS

1. Determine the actual heating and cooling loads at the desired dry bulb and wet bulb conditions.
2. Obtain the following design parameters: Entering water temperature, water flow rate in GPM, airflow in CFM, water flow pressure drop and design wet and dry bulb temperatures. Airflow CFM should be between 300 and 450 CFM per ton. Unit water pressure drop should be kept as close as possible to each other to make water balancing easier. Go to the appropriate tables and find the proper indicated water flow and water temperature.
3. Select a unit based on total and sensible cooling conditions. Select a unit which is closest to, but no larger than, the actual cooling load.
4. Enter tables at the design water flow and water temperature. Read the total and sensible cooling capacities

Note: interpolation is permissible, extrapolation is not.

5. Read the heating capacity. If it exceeds the design criteria it is acceptable. It is quite normal for water-source heat pumps to be selected on cooling capacity only since the heating output is usually greater than the cooling capacity.
6. Determine the correction factors associated with the variable factors of dry bulb and wet bulb.

Corrected Total Cooling =
tabulated total cooling x wet bulb correction.

Corrected Sensible Cooling =
tabulated sensible cooling x wet/dry bulb correction.

7. Compare the corrected capacities to the load requirements. Normally if the capacities are within 10% of the loads, the equipment is acceptable. It is better to undersize than oversize, as undersizing improves humidity control, reduces sound levels and extends the life of the equipment.
8. When completed, calculate water temperature rise and assess the selection. If the units selected are not within 10% of the load calculations, then review what effect changing the GPM, water temperature and/or air flow and air temperature would have on the corrected capacities. If the desired capacity cannot be achieved, select the next larger or smaller unit and repeat the procedure. Remember, when in doubt, undersize slightly for best performance.

EXAMPLE EQUIPMENT SELECTION FOR COOLING

Step 1: Load Determination

Assume we have determined that the appropriate cooling load at the desired dry bulb 80°F and wet bulb 65°F conditions is as follows:

Total Cooling 22,000 Btuh
Sensible Cooling 18,200 Btuh
Entering Air Temp..... 80°F Dry Bulb / 65°F Wet Bulb

Step 2: Design Conditions

Similarly, we have also obtained the following design parameters:

Entering Water Temp 90°F
Water Flow (Based upon 10°F rise in temp) .45 GPM
Airflow 600 CFM

Steps 3, 4, and 5: HP Selection

After making our preliminary selection (SZ024), we enter the tables at design water flow and water temperature and read Total Cooling, Sensible Cooling and Heat of Rejection capacities:

Total Cooling 22,500 Btuh
Sensible Cooling 16,500 Btuh
Heat of Rejection 28,800 Btuh

Steps 6 and 7: Entering Airflow Corrections

Next, we determine our correction factors.

Corrected Values	Table	Ent Air	Airflow	Corrected
Corrected Total Cooling	= 22,500 x	0.976	x 0.967	= 21,235
Corrected Sensible Cooling	= 16,500 x	0.919	x 1.089	= 16,513
Corrected Heat of Rejection	= 28,800 x	0.969	x 0.972	= 27,126

Step 8: Water Temperature Rise Calculation and Assessment

Actual Temperature Rise 12.1°F

When we compare the Corrected Total Cooling and Corrected Sensible Cooling figures with our load requirements stated in Step 1, we discover that our selection is within ±10% of our sensible load requirement. Furthermore, we see that our Corrected Total Cooling figure is within 1,000 Btuh the actual indicated load.

Model Nomenclature

Models:
SZ
024-060

1 2 3 4 5 6 7 8 9 10 11 12 13 14 15
S Z L O 2 4 A G D R O R O V S

MODEL

S = R-454B Refrigerant

MODEL TYPE

Z = Versatile Two-Stage Series

SUPPLY & RETURN CONFIGURATIONS

Horizontal Configuration

	Left	Right
Straight	L	R
Back	B	P

Vertical Configuration

	Left	Right
Top	T	K

SIZE

024 042
030 048
036 060

REVISION

A = Current

VOLTAGE¹

G = 208/230-1-60 J = 208/230-1-60 Refrigerant Detection System

CONTROLS

Control	Standard	Soft Start
DXM2.5	D	4
DXM2.5 with Disconnect	B	-

CABINET

R = Residential

STANDARD

S = Standard

BLOWER MOTOR

V = Constant Volume (CV) EC

EXTENDED OPTIONS

O = Standard
P = HWG and Pump

DRAIN PAN/HEAT EXCHANGER OPTIONS

	Standard Drain Pan	Stainless-Steel Drain Pan
Non-coated Air Coil	C	S
Tin-coated Air Coil	T	R

WATER/HEAT EXCHANGER OPTIONS²

Water Option	Standard	Cupro-Nickel
None	O	Z
MOD Valve, Low System Pressure Drop	C	-
MOD Valve, High System Pressure Drop	-	P
Internal Flow Controller Standard Head with Check Valve	1	-
Internal Flow Controller Standard Head w/o Check Valve	G	
Internal Flow Controller High Head with Check Valve	2	
Internal Flow Controller High Head w/o Check Valve	H	

NOTES:

- SZ size 060 requires J voltage.
- All Open Loop vFlow Water Circuit Options require a Cupro-Nickel Heat Exchanger.

ClimateMaster works continually to improve its products. As a result, the design and specifications of each product at the time of order may be changed without notice and may not be as described herein. Please contact ClimateMaster's Customer Service Department at 800-299-9747 for specific information on the current design and specifications. Statements and other information contained herein are not express warranties and do not form the basis of any bargain between the parties, but are merely ClimateMaster's opinion or commendation of its products. The latest version of this document is available at www.climatemaster.com. Engineered and assembled in the USA. © ClimateMaster, Inc. All Rights Reserved 2024

Performance Data: AHRI/ASHRAE/ISO 13256-1

Models:
SZ
024-060

ASHRAE/AHRI/ISO 13256-1 English (I-P) Units Part Load

Model	Motor Type	WSHP (Part Load)											
		Water Loop Heat Pump				Ground Water Heat Pump				Ground Loop Heat Pump			
		Cooling 86°F		Heating 68°F		Cooling 59°F		Heating 50°F		Cooling 68°F		Heating 41°F	
		Capacity Btuh	EER Btuh/W	Capacity Btuh	COP	Capacity Btuh	EER Btuh/W	Capacity Btuh	COP	Capacity Btuh	EER Btuh/W	Capacity Btuh	COP
SZ024	EC	17,500	17.0	19,900	5.7	20,000	29.7	16,600	4.8	19,300	25.3	14,600	4.2
SZ030	EC	21,200	15.2	24,400	5.1	24,700	26.4	20,800	4.4	23,400	22.0	18,700	4.0
SZ036	EC	26,100	16.1	31,600	5.3	29,900	26.0	25,700	4.4	28,500	22.6	22,600	4.1
SZ042	EC	32,500	17.0	36,000	5.1	36,000	28.5	29,800	4.5	35,000	23.5	26,400	4.0
SZ048	EC	34,000	16.5	39,000	5.5	38,500	28.5	31,800	4.5	37,000	24.0	28,000	4.0
SZ060	EC	42,000	17.5	47,300	5.5	47,000	29.0	38,500	4.7	45,500	24.9	34,000	4.2

Notes:

- Where dual voltages are available ratings are based on the lower voltage setting.
- Cooling capacities based upon 80.6°F DB, 66.2°F WB entering air temperature.
- Heating capacities based upon 68°F DB, 59°F WB entering air temperature.
- Ground Loop Heat Pump ratings based on 15% antifreeze solution.

ASHRAE/AHRI/ISO 13256-1 English (I-P) Units Full Load

Model	Motor Type	WSHP (Full Load)											
		Water Loop Heat Pump				Ground Water Heat Pump				Ground Loop Heat Pump			
		Cooling 86°F		Heating 68°F		Cooling 59°F		Heating 50°F		Full Cooling 77°F		Full Heating 32°F	
		Capacity Btuh	EER Btuh/W	Capacity Btuh	COP	Capacity Btuh	EER Btuh/W	Capacity Btuh	COP	Capacity Btuh	EER Btuh/W	Capacity Btuh	COP
SZ024	EC	24,000	15.1	28,400	5.3	27,000	24.1	23,500	4.7	25,000	18.0	18,400	3.9
SZ030	EC	28,700	14.0	33,200	4.6	32,900	21.7	28,700	4.1	30,200	16.3	23,200	3.6
SZ036	EC	35,000	14.0	44,200	4.6	39,300	20.2	36,300	4.2	36,400	16.4	28,600	3.6
SZ042	EC	43,000	15.5	49,500	4.7	47,500	22.8	41,000	4.2	44,500	17.3	32,500	3.5
SZ048	EC	47,500	15.5	55,000	4.8	52,000	22.9	45,000	4.3	49,000	17.7	36,000	3.7
SZ060	EC	59,000	15.5	67,200	5.0	65,000	22.8	55,700	4.4	61,500	17.8	44,600	3.7

Notes:

- Where dual voltages are available ratings are based on the lower voltage setting.
- Cooling capacities based upon 80.6°F DB, 66.2°F WB entering air temperature.
- Heating capacities based upon 68°F DB, 59°F WB entering air temperature.
- Ground Loop Heat Pump ratings based on 15% antifreeze solution.

Performance Data: AHRI/ASHRAE/ISO 13256-1

Models:
SZ
024-060

ASHRAE/AHRI/ISO 13256-1 Metric (S-I) Units Part Load

Model	Motor Type	WSHP (Part Load)											
		Water Loop Heat Pump				Ground Water Heat Pump				Ground Loop Heat Pump			
		Cooling 30°C		Heating 20°C		Cooling 15°C		Heating 10°C		Cooling 25°F		Heating 0°F	
		Capacity kW	EER W/W	Capacity kW	COP	Capacity kW	EER W/W	Capacity kW	COP	Capacity kW	EER W/W	Capacity kW	COP
SZ024	EC	5	5.0	6	5.7	6	8.7	5	4.8	6	7.4	4	4.2
SZ030	EC	6	4.5	7	5.1	7	7.7	6	4.4	7	6.5	5	4.0
SZ036	EC	8	4.7	9	5.3	9	7.6	8	4.4	8	6.6	7	4.1
SZ042	EC	10	5.0	11	5.1	11	8.4	9	4.5	10	6.9	8	4.0
SZ048	EC	10	4.8	11	5.5	11	8.4	9	4.5	11	7.0	8	4.0
SZ060	EC	12	5.1	14	5.5	14	8.5	11	4.7	13	7.3	10	4.2

Notes:

- Where dual voltages are available ratings are based on the lower voltage setting.
- Cooling capacities based upon 20°C DB, 15°C WB entering air temperature.
- Heating capacities based upon 20°C DB, 15°C WB entering air temperature.
- Ground Loop Heat Pump ratings based on 15% antifreeze solution.

ASHRAE/AHRI/ISO 13256-1 Metric (S-I) Units Full Load

Model	Motor Type	WSHP (Full Load)											
		Water Loop Heat Pump				Ground Water Heat Pump				Ground Loop Heat Pump			
		Cooling 30°C		Heating 30°C		Cooling 15°C		Heating 10°C		Full Cooling 25°F		Full Heating 0°F	
		Capacity kW	EER W/W	Capacity kW	COP	Capacity kW	EER W/W	Capacity Btuh	COP	Capacity kW	EER W/W	Capacity kW	COP
SZ024	EC	7	4.4	8	5.3	8	7.1	7	4.7	7	5.3	5	3.9
SZ030	EC	8	4.1	10	4.6	10	6.4	8	4.1	9	4.8	7	3.6
SZ036	EC	10	4.1	13	4.6	12	5.9	11	4.2	11	4.8	8	3.6
SZ042	EC	13	4.5	15	4.7	14	6.7	12	4.2	13	5.1	10	3.5
SZ048	EC	14	4.5	16	4.8	15	6.7	13	4.3	14	5.2	11	3.7
SZ060	EC	17	4.5	20	5.0	19	6.7	16	4.4	18	5.2	13	3.7

Notes:

- Where dual voltages are available ratings are based on the lower voltage setting.
- Cooling capacities based upon 27°C DB, 19°C WB entering air temperature.
- Heating capacities based upon 20°C DB, 15°C WB entering air temperature.
- Ground Loop Heat Pump ratings based on 15% antifreeze solution.

Performance Data: Selection Notes

Models:
SZ
024-060

For operation in the shaded area when water is used instead of an antifreeze solution, the LWT (Leaving Water Temperature) must be calculated. Flow must be maintained to a level such that the LWT is maintained above 40°F (4.4°C) when the JW3 jumper is not clipped (see example below). Otherwise, appropriate levels of a proper antifreeze solution should be used in systems with leaving water temperatures of 40°F (4.4°C) or below and the JW3 jumper should be clipped. This is due to the potential of the refrigerant temperature being as low as 32°F (0°C) with 40°F (4.4°C) LWT, which may lead to a nuisance cutout due to the activation of the Low Temperature Protection. JW3 should never be clipped for standard-range equipment or systems without antifreeze.

Example:

At 50°F EWT (Entering Water Temperature) and 1.5 GPM/ton, a 3-ton unit has a HE of 22,500 Btuh. To calculate LWT, rearrange the formula for HE as follows:

HE = TD x GPM x 500, where HE = Heat of Extraction (Btuh); TD = temperature difference (EWT - LWT) and GPM = U.S. Gallons per Minute.

$$TD = HE / (GPM \times 500)$$

$$TD = 22,500 / (1.5 \times 500)$$

$$TD = 10^\circ\text{F}$$

$$LWT = EWT - TD$$

$$LWT = 50 - 10 = 40^\circ\text{F}$$

In this example, as long as the EWT does not fall below 50°F, the system will operate as designed. For EWTs below 50°F, higher flow rates will be required (open loop systems, for example, require at least 2 GPM/ton when EWT is below 50°F).

Heating - EAT 70°F						
	EER	HC	Power kW	HE	LAT	COP
Not Recommended						
		4.0	0.45	2.5	84.6	2.6
8.6	27.4	4.6	0.46	3.0	86.8	2.9
8.6	31.0	4.8	0.47	3.2	87.8	3.0
8.6	33.0	4.9	0.47	3.3	88.3	3.1
8.4	23.3	5.4	0.48	3.8	90.2	3.3
8.5	26.3	5.7	0.49	4.0	91.4	3.4
8.6	27.9	5.9	0.49	4.2	92.1	3.5
8.2	19.8	6.2	0.50	4.5	93.6	3.7
4	22.3	6.6	0.50	4.9	95.0	3.8
	23.7	6.8	0.51	5.0	95.8	3.9
	16.7	7.0	0.51	5.3	96.9	4.0
	8.8	7.4	0.52	5.6	98.5	4.1
		7.6	0.52	5.8	99.3	4.2
			0.53	6.0		

Models:
SZ
024-060

EWT °F	GPM	WPD		COOLING - EAT 80/67°F							GPM	WPD		HEATING - EAT 70°F						
		PSI	FT	TC	SC	KW	HR	EER	LWT	HWG Cap		PSI	FT	HC	KW	HE	COP	LWT	HWG Cap	
20	Operation Not Recommended										4.3	2.6	5.9	10.7	1.10	6.8	2.8	16.9	1.4	
30	1.6	0.5	1.1	21.2	15.3	0.65	23.4	32.6	60.0	0.4	2.2	0.8	1.9	12.2	1.11	8.2	3.2	22.5	1.5	
											3.2	1.4	3.3	12.7	1.12	8.7	3.3	24.6	1.5	
											4.3	2.1	4.7	13.0	1.12	9.0	3.4	25.8	1.6	
40	2.3	0.7	1.6	20.6	14.9	0.67	22.9	30.6	60.0	0.4	2.2	0.6	1.5	14.2	1.12	10.2	3.7	30.7	1.6	
											3.2	1.1	2.6	14.8	1.13	10.8	3.9	33.2	1.7	
											4.3	1.7	3.9	15.2	1.13	11.2	3.9	34.8	1.7	
50	2.2	0.5	1.1	20.2	14.9	0.76	22.9	26.5	70.8	0.6	2.2	0.5	1.1	16.2	1.14	12.2	4.2	38.9	1.8	
	3.2	0.9	2.1	20.5	15.0	0.69	22.9	29.7	64.3	0.6	3.2	0.9	2.1	16.9	1.14	12.9	4.4	41.9	1.8	
	4.3	1.4	3.3	20.6	14.9	0.65	22.9	31.5	60.6	1.1	4.3	1.4	3.3	17.4	1.14	13.3	4.5	43.8	1.9	
60	2.2	0.4	1.0	19.5	14.6	0.89	22.6	22.0	80.6	1.0	2.2	0.4	1.0	18.2	1.15	14.1	4.6	47.2	2.0	
	3.2	0.8	1.8	20.0	14.8	0.80	22.9	24.9	74.3	0.9	3.2	0.8	1.8	19.0	1.15	14.9	4.8	50.7	2.0	
	4.3	1.3	2.9	20.2	14.9	0.76	22.9	26.6	70.7	1.6	4.3	1.3	2.9	19.5	1.16	15.4	4.9	52.9	2.1	
70	2.2	0.4	0.9	18.5	14.2	1.03	22.1	18.0	90.1	1.5	2.2	0.4	0.9	20.1	1.16	15.9	5.1	55.5	2.2	
	3.2	0.7	1.7	19.2	14.5	0.93	22.5	20.5	84.0	1.3	3.2	0.7	1.7	20.9	1.16	16.8	5.3	59.5	2.2	
	4.3	1.2	2.7	19.5	14.6	0.89	22.6	22.0	80.5	2.2	4.3	1.2	2.7	21.5	1.17	17.3	5.4	61.9	2.3	
80	2.2	0.4	0.8	17.4	13.6	1.18	21.6	14.7	99.6	2.0	2.2	0.4	0.8	21.9	1.17	17.7	5.5	63.9	2.4	
	3.2	0.7	1.6	18.1	14.0	1.08	21.9	16.7	93.7	1.9	3.2	0.7	1.6	22.8	1.17	18.6	5.7	68.4	2.4	
	4.3	1.1	2.6	18.5	14.2	1.03	22.1	18.0	90.3	3.0	4.3	1.1	2.6	23.4	1.18	19.2	5.8	71.1	2.5	
90	2.2	0.3	0.8	16.1	13.0	1.35	20.9	12.0	109.0	2.7	1.9	0.2	0.5	23.2	1.23	19.0	5.5	70.0	2.6	
	3.2	0.7	1.5	16.9	13.4	1.25	21.3	13.6	103.3	2.5										
	4.3	1.1	2.6	17.3	13.6	1.19	21.5	14.6	100.0	3.8										
100	2.2	0.3	0.8	15.0	12.4	1.53	20.4	9.8	118.5	3.5	1.3	0.1	0.2	23.2	1.23	19.0	5.5	70.0	2.6	
	3.2	0.6	1.5	15.6	12.8	1.42	20.7	11.0	112.9	3.2										
	4.3	1.1	2.5	16.1	13.0	1.36	20.9	11.8	109.7	4.8										
110	2.2	0.3	0.7	13.9	12.0	1.73	20.0	8.0	128.2	4.4	0.9	0.1	0.2	23.2	1.23	19.0	5.5	70.0	2.6	
	3.2	0.6	1.4	14.5	12.2	1														

- ClimateMaster works continually to improve its products. As a result, the design and specifications of each product at the time of order may be changed without notice and may not be as described herein. Please contact ClimateMaster's Customer Service Department at 800-299-9747 for specific information on the current design and specifications. Statements and other information contained herein are not express warranties and do not form the basis of any bargain between the parties, but are merely ClimateMaster's opinion or commendation of its products. The latest version of this document is available at www.climatemaster.com. Engineered and assembled in the USA. © ClimateMaster, Inc. All Rights Reserved 2024

Performance Data SZ*024 EC Blower Motor (Full Load)

Models:
SZ
024-060

800 CFM Rated Airflow

EWT °F	GPM	WPD		COOLING - EAT 80/67°F							GPM	WPD		HEATING - EAT 70°F						
		PSI	FT	TC	SC	kW	HR	EER	LWT	HWG Cap		PSI	FT	HC	kW	HE	COP	LWT	HWG Cap	
20	Operation Not Recommended										6.0	4.4	10.1	15.7	1.45	10.5	3.2	16.5	1.9	
30	2.1	0.7	1.7	28.1	20.1	1.16	32.1	24.2	60.0	1.2	3.0	1.3	3.1	17.4	1.48	12.1	3.4	21.9	2.0	
											4.5	2.4	5.6	18.2	1.49	12.9	3.6	24.3	2.1	
											6.0	3.5	8.1	18.6	1.50	13.3	3.6	25.6	2.1	
40	3.2	1.1	2.6	27.6	19.7	1.17	31.5	23.6	60.0	1.2	3.0	1.0	2.4	20.1	1.53	14.7	3.9	30.2	2.3	
											4.5	1.9	4.5	21.0	1.54	15.5	4.0	33.1	2.3	
											6.0	2.9	6.6	21.5	1.55	16.0	4.1	34.7	2.4	
50	3.0	0.8	1.9	26.8	19.4	1.23	31.2	21.8	70.8	1.5	3.0	0.8	1.9	22.8	1.58	17.2	4.2	38.6	2.5	
	4.5	1.6	3.7	27.3	19.7	1.16	31.5	23.6	64.0	1.3	4.5	1.6	3.7	23.9	1.60	18.2	4.4	41.9	2.6	
	6.0	2.5	5.7	27.5	19.7	1.12	31.5	24.5	60.5	1.2	6.0	2.5	5.7	24.4	1.61	18.7	4.4	43.8	2.7	
60	3.0	0.7	1.6	25.8	19.0	1.34	30.6	19.2	80.4	1.9	3.0	0.7	1.6	25.5	1.63	19.7	4.6	46.9	2.8	
	4.5	1.4	3.2	26.5	19.3	1.26	31.0	21.0	73.8	1.7	4.5	1.4	3.2	26.7	1.66	20.8	4.7	50.8	2.9	
	6.0	2.2	5.1	26.8	19.5	1.22	31.2	21.9	70.4	1.6	6.0	2.2	5.1	27.4	1.67	21.4	4.8	52.9	3.0	
70	3.0	0.6	1.5	24.5	18.3	1.49	29.8	16.5	89.9	2.4	3.0	0.6	1.5	28.1	1.69	22.1	4.9	55.3	3.1	
	4.5	1.3	3.0	25.4	18.8	1.39	30.3	18.3	83.5	2.2	4.5	1.3	3.0	29.5	1.72	23.4	5.0	59.6	3.2	
	6.0	2.1	4.8	25.8	19.0	1.34	30.6	19.2	80.2	2.0	6.0	2.1	4.8	30.3	1.74	24.1	5.1	62.0	3.3	
80	3.0	0.6	1.4	23.2	17.6	1.66	29.1	14.0	99.4	3.1	3.0	0.6	1.4	30.8	1.75	24.6	5.2	63.6	3.5	
	4.5	1.2	2.9	24.1	18.1	1.54	29.6	15.6	93.1	2.9	4.5	1.2	2.9	32.3	1.78	25.9	5.3	68.5	3.6	
	6.0	2.0	4.6	24.5	18.3	1.49	29.8	16.5	89.9	2.6	6.0	2.0	4.6	33.1	1.80	26.7	5.4	71.1	3.7	
90	3.0	0.6	1.4	21.8	17.0	1.87	28.5	11.7	109.0	3.9	2.6	0.4	0.9	32.8	1.87	26.4	5.1	70.0	3.8	
	4.5	1.2	2.8	22.7	17.4	1.73	28.9	13.1	102.8	3.6										
	6.0	2.0	4.6	23.1	17.6	1.66	29.1	13.9	99.7	3.3										
100	3.0	0.6	1.3	20.6	16.4	2.14	28.2	9.6	118.8	4.8	1.8	0.1	0.2	32.8	1.87	26.4	5.1	70.0	3.8	
	4.5	1.2	2.7	21.3	16.7	1.97	28.3	10.9	112.6	4.4										
	6.0	1.9	4.5	21.8	16.9	1.89	28.5	11.5	109.5	4.0										
110	3.0	0.5	1.2	19.5	16.0	2.47	28.3	7.9	128.8	5.8	1.3	0.1	0.2	32.8	1.87	26.4	5.1	70.0	3.8	
	4.5	1.1	2.6	20.1	16.2	2.26	28.1	8.9	122.5	5.3										
	6.0	1.8	4.2	20.5	16.4	2.16	28.2	9.5	119.4	4.9										
120	3.0	0.4	1.0	18.8	16.0	2.89	29.0	6.5	139.4	7.0	1.1	0.1	0.2	32.8	1.87	26.4	5.1	70.0	3.8	
	4.5	0.9	2.2	19.2	16.0	2.61	28.5	7.3	132.6	6.4										
	6.0	1.6	3.8	19.4	16.0	2.49	28.3	7.8	129.4	5.8										

- Interpolation is permissible; extrapolation is not.
- All entering air conditions are 80°F (26.6°C) DB and 67°F (19.4°C) WB in cooling, and 70°F (21°C) DB in heating.
- AHRI/ISO certified conditions are 80.6°F (27°C) DB and 66.2°F (19°C) WB in cooling and 68°F (20°C) DB in heating.
- Table does not reflect fan or pump power corrections for AHRI/ISO conditions.
- All performance is based upon the lower voltage of dual voltage rated units.
- Performance stated is at the rated power supply; performance may vary as the power supply varies from the rated.
- Operation below 40°F (10.0°C) EWT is based upon 20% methanol antifreeze solution.
- Operation below 60°F (15.5°C) EWT requires optional insulated water/refrigerant circuit.
- See performance correction tables for operating conditions other than those listed above.
- See Performance Data Selection Notes for operation in the shaded areas.
- Regular Cooling operation with an EWT of less than 50°F (10.0°C) is not recommended unless variable water flow is available.
- Regular Heating operation with an EWT of more than 90°F (32°C) is not recommended unless variable water flow is available.
- For quiet operation and long term reliability, it is recommended that systems be designed to avoid continuous operation in the outlined areas.
- Performance capacities shown in thousands of Btuh
- Hot Water Generator Capacity is based on 90°F entering water and 0.5 GPM/Ton.

Performance Data SZ*030 EC Blower Motor (Part Load)

Models:
SZ
024-060

750 CFM Rated Airflow

EWT °F	GPM	WPD		COOLING - EAT 80/67°F							GPM	WPD		HEATING - EAT 70°F						
		PSI	FT	TC	SC	kW	HR	EER	LWT	HWG Cap		PSI	FT	HC	kW	HE	COP	LWT	HWG Cap	
20	Operation Not Recommended										5.5	3.6	8.3	14.7	1.47	9.5	2.9	16.5	1.4	
30	1.9	0.5	1.1	25.3	18.0	0.89	28.3	28.5	60.0	0.2	2.8	1.1	2.5	16.3	1.50	11.0	3.2	22.1	1.5	
											4.1	2.0	4.5	17.0	1.51	11.6	3.3	24.3	1.5	
											5.5	2.9	6.6	17.3	1.51	12.0	3.4	25.7	1.6	
40	2.8	0.8	1.8	25.1	18.0	0.92	28.2	27.4	60.0	0.2	2.8	0.8	1.8	18.7	1.53	13.2	3.6	30.5	1.6	
											4.1	1.5	3.5	19.4	1.54	13.9	3.7	33.2	1.7	
											5.5	2.3	5.4	19.8	1.54	14.4	3.8	34.8	1.7	
50	2.8	0.6	1.4	24.3	17.6	1.02	27.9	24.0	70.0	0.7	2.8	0.6	1.4	21.0	1.55	15.4	4.0	39.0	1.8	
	4.1	1.2	2.9	24.8	17.8	0.93	28.1	26.8	63.7	0.6	4.1	1.2	2.8	21.8	1.56	16.2	4.1	42.1	1.9	
	5.5	2.0	4.6	25.1	18.0	0.88	28.2	28.4	60.3	0.6	5.5	2.0	4.6	22.3	1.56	16.7	4.2	43.9	1.9	
60	2.8	0.5	1.1	23.4	17.2	1.17	27.6	20.0	79.7	1.2	2.8	0.5	1.1	23.2	1.57	17.6	4.3	47.4	2.0	
	4.1	1.1	2.4	24.0	17.5	1.07	27.8	22.4	73.6	1.1	4.1	1.1	2.4	24.1	1.57	18.5	4.5	51.0	2.1	
	5.5	1.8	4.1	24.3	17.6	1.02	27.9	23.9	70.2	1.0	5.5	1.8	4.1	24.6	1.57	19.0	4.6	53.1	2.2	
70	2.8	0.4	1.0	22.4	16.8	1.35	27.2	16.6	89.4	1.9	2.8	0.4	1.0	25.3	1.58	19.7	4.7	55.9	2.3	
	4.1	1.0	2.2	23.1	17.0	1.24	27.5	18.6	83.4	1.7	4.1	1.0	2.2	26.3	1.58	20.7	4.9	59.9	2.3	
	5.5	1.7	3.8	23.4	17.2	1.18	27.6	19.9	80.0	1.6	5.5	1.7	3.8	26.9	1.58	21.3	5.0	62.3	2.4	
80	2.8	0.4	0.9	21.3	16.3	1.55	26.8	13.7	99.2	2.6	2.8	0.4	0.9	27.4	1.59	21.8	5.1	64.4	2.5	
	4.1	0.9	2.1	22.0	16.6	1.43	27.1	15.4	93.2	2.4	4.1	0.9	2.1	28.5	1.60	22.8	5.2	68.9	2.6	
	5.5	1.6	3.7	22.4	16.7	1.36	27.2	16.4	89.9	2.2	5.5	1.6	3.7	29.1	1.60	23.4	5.3	71.5	2.7	
90	2.8	0.4	0.9	20.2	15.7	1.77	26.4	11.4	108.9	3.5	2.3	0.2	0.4	28.8	1.66	23.1	5.1	70.0	2.8	
	4.1	0.9	2.0	20.9	16.1	1.64	26.7	12.8	103.0	3.2										
	5.5	1.6	3.6	21.3	16.2	1.56	26.8	13.6	99.7	2.9										
100	2.8	0.4	0.9	18.9	15.2	2.01	26.1	9.4	118.6	4.4	1.5	0.1	0.2	28.8	1.66	23.1	5.1	70.0	2.8	
	4.1	0.9	2.0	19.7	15.5	1.86	26.3	10.6	112.8	4.1										
	5.5	1.5	3.5	20.1	15.7	1.79	26.4	11.2	109.6	3.7										
110	2.8	0.3	0.8	17.7	14.6	2.26	25.7	7.8	128.4	5.4	1.2	0.1	0.2	28.8	1.66	23.1	5.1	70.0	2.8	
	4.1	0.8	1.8	18.4	14.9	2.11	25.9	8.7	122.6	5.0										
	5.5	1.4	3.2	18.8	15.1	2.03	26.0	9.3	119.5	4.5										
120	2.8	0.2	0.5	16.4	14.0	2.52	25.4	6.5	138.1	6.6	0.9	0.1	0.2	28.8	1.66	23.1	5.1	70.0	2.8	
	4.1	0.6	1.5	17.2	14.3	2.37	25.6	7.2	132.5	6.0										
	5.5	1.2	2.7	17.6	14.5	2.28	25.7	7.7	129.3	5.5										

- Interpolation is permissible; extrapolation is not.
- All entering air conditions are 80°F (26.6°C) DB and 67°F (19.4°C) WB in cooling, and 70°F (21°C) DB in heating.
- AHRI/ISO certified conditions are 80.6°F (27°C) DB and 66.2°F (19°C) WB in cooling and 68°F (20°C) DB in heating.
- Table does not reflect fan or pump power corrections for AHRI/ISO conditions.
- All performance is based upon the lower voltage of dual voltage rated units.
- Performance stated is at the rated power supply; performance may vary as the power supply varies from the rated.
- Operation below 40°F (10.0°C) EWT is based upon 20% methanol antifreeze solution.
- Operation below 60°F (15.5°C) EWT requires optional insulated water/refrigerant circuit.
- See performance correction tables for operating conditions other than those listed above.
- See Performance Data Selection Notes for operation in the shaded areas.
- Regular Cooling operation with an EWT of less than 50°F (10.0°C) is not recommended unless variable water flow is available.
- Regular Heating operation with an EWT of more than 90°F (32°C) is not recommended unless variable water flow is available.
- For quiet operation and long term reliability, it is recommended that systems be designed to avoid continuous operation in the outlined areas.
- Performance capacities shown in thousands of Btuh
- Hot Water Generator Capacity is based on 90°F entering water and 0.5 GPM/Ton.

Performance Data

SZ*030 EC Blower Motor (Full Load)

Models:
SZ
024-060

900 CFM Rated Airflow

EWT °F	GPM	WPD		COOLING - EAT 80/67°F							GPM	WPD		HEATING - EAT 70°F						
		PSI	FT	TC	SC	kW	HR	EER	LWT	HWG Cap		PSI	FT	HC	kW	HE	COP	LWT	HWG Cap	
20	Operation Not Recommended										7.5	6.0	13.8	20.9	1.93	14.0	3.2	16.3	1.9	
30	2.6	0.8	1.9	33.8	22.9	1.49	38.8	22.7	60.0	1.0	3.8	1.8	4.1	22.8	1.98	15.8	3.4	21.7	2.0	
											5.6	3.3	7.5	23.6	2.01	16.5	3.5	24.1	2.0	
											7.5	4.8	11.0	24.1	2.02	16.9	3.5	25.5	2.1	
40	3.9	1.4	3.2	33.6	22.8	1.51	38.7	22.2	60.0	1.0	3.8	1.3	3.1	25.8	2.07	18.5	3.7	30.3	2.2	
											5.6	2.6	5.9	26.8	2.10	19.3	3.7	33.1	2.3	
											7.5	3.9	9.0	27.4	2.11	19.8	3.8	34.7	2.3	
50	3.8	1.0	2.4	32.6	22.4	1.60	38.3	20.4	70.2	1.5	3.8	1.0	2.4	28.8	2.15	21.2	3.9	38.9	2.5	
	5.6	2.1	4.8	33.2	22.7	1.50	38.6	22.1	63.8	1.4	5.6	2.1	4.8	29.9	2.19	22.2	4.0	42.1	2.6	
	7.5	3.3	7.6	33.6	22.8	1.45	38.7	23.1	60.3	1.3	7.5	3.3	7.6	30.6	2.20	22.8	4.1	43.9	2.6	
60	3.8	0.9	2.0	31.5	22.0	1.77	37.8	17.8	79.9	2.1	3.8	0.9	2.0	31.8	2.24	23.9	4.2	47.4	2.9	
	5.6	1.8	4.2	32.2	22.3	1.66	38.1	19.4	73.6	2.0	5.6	1.8	4.2	33.1	2.27	25.0	4.3	51.1	3.0	
	7.5	3.0	6.8	32.6	22.4	1.60	38.3	20.3	70.2	1.8	7.5	3.0	6.8	33.8	2.29	25.6	4.3	53.2	3.0	
70	3.8	0.8	1.8	30.3	21.5	1.97	37.3	15.4	89.6	2.9	3.8	0.8	1.8	34.8	2.32	26.5	4.4	56.0	3.3	
	5.6	1.7	3.8	31.1	21.8	1.84	37.6	16.9	83.4	2.6	5.6	1.7	3.8	36.1	2.36	27.7	4.5	60.1	3.4	
	7.5	2.8	6.4	31.5	22.0	1.78	37.8	17.7	80.1	2.4	7.5	2.8	6.4	36.9	2.38	28.5	4.5	62.4	3.5	
80	3.8	0.7	1.7	28.9	20.9	2.20	36.8	13.1	99.3	3.7	3.8	0.7	1.7	37.7	2.40	29.1	4.6	64.7	3.8	
	5.6	1.6	3.7	29.8	21.3	2.05	37.1	14.5	93.2	3.4	5.6	1.6	3.7	39.1	2.45	30.4	4.7	69.1	3.9	
	7.5	2.7	6.3	30.2	21.4	1.98	37.3	15.3	89.9	3.1	7.5	2.7	6.3	40.0	2.47	31.2	4.7	71.7	4.0	
90	3.8	0.7	1.7	27.5	20.3	2.46	36.2	11.2	109.1	4.6	3.1	0.3	0.7	39.5	2.56	30.7	4.5	70.0	4.4	
	5.6	1.6	3.7	28.4	20.7	2.30	36.6	12.4	103.1	4.2										
	7.5	2.7	6.2	28.9	20.9	2.21	36.7	13.1	99.8	3.8										
100	3.8	0.7	1.7	25.9	19.6	2.76	35.7	9.4	118.8	5.6	2.0	0.1	0.2	39.5	2.56	30.7	4.5	70.0	4.4	
	5.6	1.5	3.6	26.9	20.0	2.57	36.0	10.4	112.9	5.2										
	7.5	2.6	6.1	27.4	20.2	2.48	36.2	11.0	109.7	4.7										
110	3.8	0.7	1.5	24.3	18.8	3.10	35.3	7.8	128.6	6.8	1.5	0.1	0.2	39.5	2.56	30.7	4.5	70.0	4.4	
	5.6	1.4	3.3	25.3	19.3	2.89	35.6	8.7	122.7	6.2										
	7.5	2.5	5.8	25.8	19.5	2.78	35.7	9.3	119.5	5.6										
120	3.8	0.5	1.2	22.6	17.9	3.48	34.9	6.5	138.4	8.0	1.2	0.1	0.2	39.5	2.56	30.7	4.5	70.0	4.4	
	5.6	1.2	2.9	23.6	18.4	3.25	35.1	7.3	132.5	7.3										
	7.5	2.2	5.1	24.1	18.7	3.13	35.3	7.7	129.4	6.6										

- Interpolation is permissible; extrapolation is not.
- All entering air conditions are 80°F (26.6°C) DB and 67°F (19.4°C) WB in cooling, and 70°F (21°C) DB in heating.
- AHRI/ISO certified conditions are 80.6°F (27°C) DB and 66.2°F (19°C) WB in cooling and 68°F (20°C) DB in heating.
- Table does not reflect fan or pump power corrections for AHRI/ISO conditions.
- All performance is based upon the lower voltage of dual voltage rated units.
- Performance stated is at the rated power supply; performance may vary as the power supply varies from the rated.
- Operation below 40°F (10.0°C) EWT is based upon 20% methanol antifreeze solution.
- Operation below 60°F (15.5°C) EWT requires optional insulated water/refrigerant circuit.
- See performance correction tables for operating conditions other than those listed above.
- See Performance Data Selection Notes for operation in the shaded areas.
- Regular Cooling operation with an EWT of less than 50°F (10.0°C) is not recommended unless variable water flow is available.
- Regular Heating operation with an EWT of more than 90°F (32°C) is not recommended unless variable water flow is available.
- For quiet operation and long term reliability, it is recommended that systems be designed to avoid continuous operation in the outlined areas.
- Performance capacities shown in thousands of Btuh
- Hot Water Generator Capacity is based on 90°F entering water and 0.5 GPM/Ton.

Performance Data

SZ*036 EC Blower Motor (Part Load)

Models:
SZ
024-060

950 CFM Rated Airflow

EWT °F	GPM	WPD		COOLING - EAT 80/67°F							GPM	WPD		HEATING - EAT 70°F						
		PSI	FT	TC	SC	kW	HR	EER	LWT	HWG Cap		PSI	FT	HC	kW	HE	COP	LWT	HWG Cap	
20	Operation Not Recommended										6.8	3.3	7.7	17.3	1.67	11.3	3.0	16.7	1.7	
30	2.3	0.4	0.9	30.7	22.7	1.10	34.4	27.9	60.0	0.2	3.4	1.0	2.3	19.2	1.70	13.1	3.3	22.3	1.7	
											5.1	1.9	4.3	19.9	1.71	13.9	3.4	24.6	1.8	
											6.8	2.8	6.5	20.4	1.71	14.3	3.5	25.8	1.8	
40	3.4	0.8	1.9	30.4	22.4	1.13	34.2	27.0	60.0	0.2	3.4	0.8	1.9	22.1	1.73	15.9	3.7	30.6	1.9	
											5.1	1.6	3.6	23.1	1.74	16.9	3.9	33.4	2.0	
											6.8	2.4	5.6	23.6	1.75	17.4	4.0	34.9	2.0	
50	3.4	0.7	1.7	29.4	22.0	1.21	33.7	24.3	69.8	0.7	3.4	0.7	1.7	25.1	1.76	18.9	4.2	38.9	2.2	
	5.1	1.4	3.1	30.1	22.3	1.12	34.1	26.8	63.4	0.7	5.1	1.4	3.1	26.4	1.77	20.1	4.4	42.1	2.2	
	6.8	2.1	4.9	30.4	22.4	1.08	34.2	28.1	60.1	0.6	6.8	2.1	4.9	27.0	1.78	20.7	4.5	43.9	2.3	
60	3.4	0.7	1.6	28.3	21.4	1.36	33.2	20.8	79.5	1.5	3.4	0.7	1.6	28.3	1.79	21.9	4.6	47.1	2.5	
	5.1	1.2	2.8	29.1	21.8	1.26	33.6	23.0	73.2	1.4	5.1	1.2	2.8	29.7	1.80	23.3	4.8	50.9	2.5	
	6.8	1.9	4.5	29.4	22.0	1.21	33.7	24.3	69.9	1.3	6.8	1.9	4.5	30.5	1.80	24.1	5.0	52.9	2.6	
70	3.4	0.6	1.5	27.0	20.8	1.54	32.5	17.6	89.1	2.4	3.4	0.6	1.5	31.4	1.81	25.0	5.1	55.3	2.8	
	5.1	1.2	2.7	27.9	21.2	1.42	32.9	19.6	82.9	2.2	5.1	1.2	2.7	33.1	1.82	26.6	5.3	59.6	2.9	
	6.8	1.8	4.2	28.3	21.4	1.37	33.1	20.7	79.7	2.0	6.8	1.8	4.2	34.0	1.83	27.4	5.4	61.9	2.9	
80	3.4	0.6	1.4	25.6	20.1	1.74	31.8	14.7	98.7	3.2	3.4	0.6	1.4	34.6	1.84	28.0	5.5	63.5	3.2	
	5.1	1.1	2.6	26.5	20.5	1.61	32.2	16.5	92.6	2.9	5.1	1.1	2.6	36.4	1.85	29.8	5.8	68.3	3.3	
	6.8	1.7	4.0	27.0	20.7	1.55	32.5	17.4	89.5	2.7	6.8	1.7	4.0	37.3	1.86	30.7	5.9	71.0	3.3	
90	3.4	0.6	1.4	24.1	19.4	1.96	31.1	12.3	108.3	4.1	3.0	0.5	1.1	37.0	1.94	30.4	5.6	70.0	3.6	
	5.1	1.1	2.5	25.1	19.8	1.82	31.5	13.8	102.4	3.7										
	6.8	1.7	3.9	25.5	20.1	1.75	31.7	14.6	99.3	3.4										
100	3.4	0.6	1.4	22.6	18.8	2.20	30.4	10.2	117.9	4.9	2.0	0.1	0.2	37.0	1.94	30.4	5.6	70.0	3.6	
	5.1	1.1	2.5	23.5	19.2	2.05	30.8	11.5	112.1	4.5										
	6.8	1.7	3.9	24.0	19.4	1.98	31.0	12.1	109.1	4.1										
110	3.4	0.6	1.3	21.0	18.3	2.47	29.8	8.5	127.5	5.8	1.5	0.1	0.2	37.0	1.94	30.4	5.6	70.0	3.6	
	5.1	1.0	2.4	21.9	18.6	2.31	30.2	9.5	121.8	5.3										
	6.8	1.6	3.8	22.4	18.7	2.23	30.3	10.0	118.9	4.9										
120	3.4	0.5	1.3	19.5	17.8	2.77	29.3	7.0	137.3	6.7	1.2	0.1	0.2	37.0	1.94	30.4	5.6	70.0	3.6	
	5.1	1.0	2.2	20.4	18.1	2.59	29.6	7.9	131.6	6.2										
	6.8	1.5	3.6	20.8	18.2	2.51	29.8	8.3	128.8	5.6										

- Interpolation is permissible; extrapolation is not.
- All entering air conditions are 80°F (26.6°C) DB and 67°F (19.4°C) WB in cooling, and 70°F (21°C) DB in heating.
- AHRI/ISO certified conditions are 80.6°F (27°C) DB and 66.2°F (19°C) WB in cooling and 68°F (20°C) DB in heating.
- Table does not reflect fan or pump power corrections for AHRI/ISO conditions.
- All performance is based upon the lower voltage of dual voltage rated units.
- Performance stated is at the rated power supply; performance may vary as the power supply varies from the rated.
- Operation below 40°F (10.0°C) EWT is based upon 20% methanol antifreeze solution.
- Operation below 60°F (15.5°C) EWT requires optional insulated water/refrigerant circuit.
- See performance correction tables for operating conditions other than those listed above.
- See Performance Data Selection Notes for operation in the shaded areas.
- Regular Cooling operation with an EWT of less than 50°F (10.0°C) is not recommended unless variable water flow is available.
- Regular Heating operation with an EWT of more than 90°F (32°C) is not recommended unless variable water flow is available.
- For quiet operation and long term reliability, it is recommended that systems be designed to avoid continuous operation in the outlined areas.
- Performance capacities shown in thousands of Btuh
- Hot Water Generator Capacity is based on 90°F entering water and 0.5 GPM/Ton.

Performance Data

SZ*036 EC Blower Motor (Full Load)

Models:
SZ
024-060

1150 CFM Rated Airflow

EWT °F	GPM	WPD		COOLING - EAT 80/67°F							GPM	WPD		HEATING - EAT 70°F						
		PSI	FT	TC	SC	kW	HR	EER	LWT	HWG Cap		PSI	FT	HC	kW	HE	COP	LWT	HWG Cap	
20	Operation Not Recommended										9.0	5.2	12.1	25.1	2.26	17.0	3.3	16.2	2.4	
30	3.1	0.7	1.5	40.0	28.3	1.87	46.3	21.4	60.0	1.2	4.5	1.6	3.6	27.4	2.32	19.2	3.5	21.5	2.4	
											6.8	3.0	6.8	28.6	2.35	20.3	3.6	24.0	2.5	
											9.0	4.4	10.1	29.2	2.36	20.8	3.6	25.4	2.6	
40	4.6	1.3	3.1	39.8	28.2	1.90	46.3	20.9	60.0	1.2	4.5	1.3	3.0	31.4	2.42	22.8	3.8	29.9	2.7	
											6.8	2.4	5.5	32.9	2.46	24.1	3.9	32.9	2.8	
											9.0	3.7	8.6	33.7	2.48	24.8	4.0	34.5	2.8	
50	4.5	1.1	2.6	38.6	27.4	1.96	45.6	19.7	70.3	1.8	4.5	1.1	2.6	35.5	2.53	26.5	4.1	38.2	3.0	
	6.8	2.0	4.7	39.4	27.9	1.87	46.0	21.1	63.5	1.6	6.8	2.0	4.7	37.3	2.58	28.1	4.2	41.7	3.1	
	9.0	3.3	7.6	39.7	28.2	1.83	46.3	21.7	60.3	1.5	9.0	3.3	7.6	38.2	2.60	29.0	4.3	43.6	3.2	
60	4.5	1.0	2.4	37.4	26.7	2.13	45.0	17.5	80.0	2.5	4.5	1.0	2.4	39.7	2.64	30.4	4.4	46.5	3.5	
	6.8	1.8	4.2	38.2	27.2	2.01	45.4	19.0	73.4	2.3	6.8	1.8	4.2	41.8	2.70	32.2	4.5	50.5	3.6	
	9.0	3.0	6.9	38.6	27.4	1.96	45.6	19.7	70.1	2.1	9.0	3.0	6.9	42.9	2.73	33.2	4.6	52.6	3.7	
70	4.5	1.0	2.2	35.9	26.0	2.34	44.3	15.4	89.7	3.4	4.5	1.0	2.2	44.0	2.77	34.2	4.7	54.8	4.1	
	6.8	1.7	4.0	36.9	26.4	2.20	44.7	16.8	83.2	3.1	6.8	1.7	4.0	46.3	2.84	36.3	4.8	59.3	4.2	
	9.0	2.8	6.5	37.4	26.7	2.13	45.0	17.5	80.0	2.9	9.0	2.8	6.5	47.6	2.88	37.3	4.8	61.7	4.3	
80	4.5	0.9	2.1	34.4	25.3	2.58	43.6	13.3	99.4	4.4	4.5	0.9	2.1	48.3	2.90	38.0	4.9	63.1	4.7	
	6.8	1.7	4.0	35.4	25.7	2.42	44.0	14.7	92.9	4.1	6.8	1.7	4.0	50.8	2.99	40.2	5.0	68.2	4.8	
	9.0	2.7	6.3	35.9	25.9	2.34	44.2	15.3	89.8	3.7	9.0	2.7	6.3	52.1	3.04	41.3	5.0	70.8	5.0	
90	4.5	0.9	2.1	32.7	24.6	2.86	42.8	11.4	109.0	5.6	4.1	0.7	1.6	51.8	3.15	41.0	4.8	70.0	5.4	
	6.8	1.7	3.9	33.8	25.0	2.67	43.3	12.6	102.7	5.1										
	9.0	2.7	6.2	34.3	25.2	2.59	43.5	13.3	99.7	4.7										
100	4.5	0.9	2.1	30.8	24.0	3.18	42.1	9.7	118.7	6.9	2.7	0.1	0.2	51.8	3.15	41.0	4.8	70.0	5.4	
	6.8	1.7	3.9	32.0	24.4	2.97	42.6	10.8	112.5	6.3										
	9.0	2.7	6.1	32.6	24.6	2.88	42.8	11.3	109.5	5.7										
110	4.5	0.9	2.0	28.9	23.3	3.53	41.4	8.2	128.4	8.3	2.1	0.1	0.2	51.8	3.15	41.0	4.8	70.0	5.4	
	6.8	1.6	3.6	30.1	23.7	3.30	41.8	9.1	122.3	7.6										
	9.0	2.6	5.9	30.7	23.9	3.20	42.1	9.6	119.3	6.9										
120	4.5	0.8	1.8	26.8	22.7	3.91	40.7	6.8	138.1	9.9	1.6	0.1	0.2	51.8	3.15	41.0	4.8	70.0	5.4	
	6.8	1.4	3.1	28.1	23.1	3.67	41.1	7.6	132.1	9.0										
	9.0	2.4	5.6	28.7	23.3	3.56	41.3	8.1	129.2	8.2										

- Interpolation is permissible; extrapolation is not.
- All entering air conditions are 80°F (26.6°C) DB and 67°F (19.4°C) WB in cooling, and 70°F (21°C) DB in heating.
- AHRI/ISO certified conditions are 80.6°F (27°C) DB and 66.2°F (19°C) WB in cooling and 68°F (20°C) DB in heating.
- Table does not reflect fan or pump power corrections for AHRI/ISO conditions.
- All performance is based upon the lower voltage of dual voltage rated units.
- Performance stated is at the rated power supply; performance may vary as the power supply varies from the rated.
- Operation below 40°F (10.0°C) EWT is based upon 20% methanol antifreeze solution.
- Operation below 60°F (15.5°C) EWT requires optional insulated water/refrigerant circuit.
- See performance correction tables for operating conditions other than those listed above.
- See Performance Data Selection Notes for operation in the shaded areas.
- Regular Cooling operation with an EWT of less than 50°F (10.0°C) is not recommended unless variable water flow is available.
- Regular Heating operation with an EWT of more than 90°F (32°C) is not recommended unless variable water flow is available.
- For quiet operation and long term reliability, it is recommended that systems be designed to avoid continuous operation in the outlined areas.
- Performance capacities shown in thousands of Btuh
- Hot Water Generator Capacity is based on 90°F entering water and 0.5 GPM/Ton.

Models:
SZ
024-060

EWT °F	GPM	WPD		COOLING - EAT 80/67°F							GPM	WPD		HEATING - EAT 70°F						
		PSI	FT	TC	SC	kW	HR	EER	LWT	HWG Cap		PSI	FT	HC	kW	HE	COP	LWT	HWG Cap	
20	Operation Not Recommended										8.5	3.3	7.7	19.2	2.06	11.9	2.7	17.2	2.7	
30	2.8	0.2	0.5	37.1	27.0	1.30	41.5	28.6	60.0	1.0	4.3	0.9	2.2	21.4	2.09	14.0	3.0	23.4	2.7	
											6.4	1.9	4.3	22.2	2.10	14.7	3.1	25.4	2.8	
											8.5	3.0	6.9	22.6	2.10	15.1	3.2	26.4	2.8	
40	4.0	0.7	1.7	35.8	25.9	1.34	40.4	26.7	60.0	1.0	4.3	0.9	2.0	24.9	2.12	17.4	3.4	31.8	2.9	
											6.4	1.7	3.9	26.0	2.13	18.4	3.6	34.2	3.0	
											8.5	2.8	6.4	26.6	2.14	19.0	3.6	35.5	3.0	
50	4.3	0.8	1.9	35.9	26.4	1.45	41.0	24.8	69.3	1.4	4.3	0.8	1.9	28.7	2.15	21.1	3.9	40.1	3.1	
	6.4	1.6	3.7	35.8	26.0	1.33	40.6	26.9	62.7	1.3	6.4	1.6	3.7	30.1	2.16	22.4	4.1	43.0	3.2	
	8.5	2.6	6.0	35.7	25.8	1.28	40.2	27.8	59.5	1.2	8.5	2.6	6.0	30.9	2.16	23.2	4.2	44.5	3.3	
60	4.3	0.8	1.9	35.3	26.3	1.66	41.2	21.3	79.4	2.0	4.3	0.8	1.9	32.6	2.18	24.9	4.4	48.3	3.4	
	6.4	1.6	3.6	35.8	26.4	1.52	41.2	23.6	72.9	1.8	6.4	1.6	3.6	34.3	2.19	26.5	4.6	51.7	3.5	
	8.5	2.5	5.8	35.9	26.4	1.46	41.1	24.6	69.7	1.7	8.5	2.5	5.8	35.1	2.19	27.4	4.7	53.6	3.6	
70	4.3	0.8	1.9	34.1	25.8	1.89	40.9	18.0	89.2	2.7	4.3	0.8	1.9	36.5	2.20	28.7	4.9	56.5	3.7	
	6.4	1.5	3.5	35.0	26.2	1.74	41.1	20.1	82.9	2.5	6.4	1.5	3.5	38.2	2.21	30.4	5.1	60.5	3.8	
	8.5	2.4	5.6	35.3	26.3	1.66	41.2	21.2	79.7	2.3	8.5	2.4	5.6	39.1	2.21	31.3	5.2	62.6	3.9	
80	4.3	0.8	1.9	32.5	24.9	2.16	40.2	15.0	98.9	3.6	4.3	0.8	1.9	40.0	2.22	32.1	5.3	64.9	4.1	
	6.4	1.5	3.5	33.6	25.5	1.99	40.7	16.9	92.7	3.3	6.4	1.5	3.5	41.8	2.23	33.8	5.5	69.4	4.2	
	8.5	2.4	5.5	34.1	25.7	1.90	40.8	17.9	89.6	3.0	8.5	2.4	5.5	42.6	2.24	34.6	5.6	71.9	4.3	
90	4.3	0.8	1.9	30.6	23.9	2.46	39.3	12.4	108.5	4.7	3.4	0.5	1.2	42.2	2.33	34.3	5.3	70.0	4.6	
	6.4	1.5	3.4	31.8	24.6	2.27	39.9	14.0	102.5	4.3										
	8.5	2.3	5.4	32.4	24.9	2.18	40.1	14.9	99.4	3.9										
100	4.3	0.8	1.8	28.4	22.9	2.78	38.3	10.2	118.0	6.0	2.3	0.1	0.2	42.2	2.33	34.3	5.3	70.0	4.6	
	6.4	1.4	3.3	29.8	23.5	2.58	38.9	11.5	112.2	5.5										
	8.5	2.3	5.2	30.4	23.8	2.48	39.2	12.3	109.2	5.0										
110	4.3	0.7	1.7	26.2	21.9	3.14	37.4	8.3	127.6	7.5	1.7	0.1	0.2	42.2	2.33	34.3	5.3	70.0	4.6	
	6.4	1.3	3.1	27.5	22.5															

- ClimateMaster works continually to improve its products. As a result, the design and specifications of each product at the time of order may be changed without notice and may not be as described herein. Please contact ClimateMaster's Customer Service Department at 800-299-9747 for specific information on the current design and specifications. Statements and other information contained herein are not express warranties and do not form the basis of any bargain between the parties, but are merely ClimateMaster's opinion or commendation of its products. The latest version of this document is available at www.climatemaster.com. Engineered and assembled in the USA. © ClimateMaster, Inc. All Rights Reserved 2024

Performance Data

SZ*042 EC Blower Motor (Full Load)

Models:
SZ
024-060

1350 CFM Rated Airflow

EWT °F	GPM	WPD		COOLING - EAT 80/67°F							GPM	WPD		HEATING - EAT 70°F						
		PSI	FT	TC	SC	kW	HR	EER	LWT	HWG Cap		PSI	FT	HC	kW	HE	COP	LWT	HWG Cap	
20	Operation Not Recommended										10.5	4.9	11.2	27.7	2.78	17.8	2.9	16.6	3.3	
30	3.6	0.4	0.9	47.2	32.7	2.14	54.5	22.0	60.0	2.3	5.3	1.4	3.1	30.1	2.85	19.9	3.1	22.4	3.3	
											7.9	2.7	6.3	31.1	2.87	20.9	3.2	24.7	3.4	
											10.5	4.3	10.0	31.7	2.88	21.5	3.2	25.9	3.5	
40	5.3	1.2	2.8	45.9	31.6	2.15	53.2	21.3	60.0	2.3	5.3	1.2	2.9	34.3	2.93	23.9	3.4	30.9	3.6	
											7.9	2.5	5.7	35.8	2.96	25.3	3.6	33.6	3.7	
											10.5	4.0	9.2	36.7	2.97	26.1	3.6	35.0	3.8	
50	5.3	1.2	2.7	46.5	32.5	2.27	54.6	20.5	70.8	2.7	5.3	1.2	2.7	39.1	3.01	28.4	3.8	39.2	4.0	
	7.9	2.3	5.3	46.2	32.0	2.13	53.8	21.7	63.6	2.5	7.9	2.3	5.3	41.0	3.04	30.2	4.0	42.4	4.1	
	10.5	3.7	8.6	45.9	31.6	2.07	53.2	22.2	60.1	2.3	10.5	3.7	8.6	42.1	3.06	31.2	4.0	44.1	4.2	
60	5.3	1.1	2.6	46.2	32.6	2.50	55.1	18.5	81.0	3.2	5.3	1.1	2.6	44.1	3.09	33.1	4.2	47.4	4.3	
	7.9	2.2	5.1	46.5	32.6	2.34	54.8	19.9	73.9	3.0	7.9	2.2	5.1	46.4	3.13	35.3	4.4	51.1	4.5	
	10.5	3.6	8.2	46.5	32.5	2.26	54.6	20.5	70.4	2.7	10.5	3.6	8.2	47.7	3.15	36.5	4.4	53.1	4.6	
70	5.3	1.1	2.6	45.1	32.1	2.77	54.9	16.3	90.9	3.9	5.3	1.1	2.6	49.2	3.17	37.9	4.5	55.6	4.8	
	7.9	2.1	4.9	45.9	32.5	2.58	55.1	17.8	83.9	3.6	7.9	2.1	4.9	51.7	3.22	40.3	4.7	59.8	4.9	
	10.5	3.5	8.0	46.2	32.6	2.49	55.1	18.6	80.5	3.3	10.5	3.5	8.0	53.1	3.25	41.5	4.8	62.1	5.1	
80	5.3	1.1	2.6	43.5	31.2	3.08	54.4	14.1	100.7	4.8	5.3	1.1	2.6	54.1	3.27	42.4	4.8	63.8	5.3	
	7.9	2.1	4.9	44.7	31.9	2.85	54.8	15.7	93.9	4.5	7.9	2.1	4.9	56.7	3.33	44.8	5.0	68.7	5.4	
	10.5	3.4	7.8	45.2	32.1	2.75	55.0	16.4	90.5	4.0	10.5	3.4	7.8	58.0	3.36	46.0	5.1	71.2	5.6	
90	5.3	1.1	2.6	41.4	30.2	3.45	53.6	12.0	110.4	6.0	4.6	0.8	1.8	57.5	3.48	45.6	4.8	70.0	5.9	
	7.9	2.1	4.8	42.9	30.9	3.18	54.2	13.5	103.7	5.5										
	10.5	3.3	7.7	43.5	31.3	3.07	54.4	14.2	100.4	5.0										
100	5.3	1.1	2.5	38.9	28.9	3.88	52.7	10.0	120.1	7.4	3.0	0.1	0.2	57.5	3.48	45.6	4.8	70.0	5.9	
	7.9	2.0	4.6	40.6	29.8	3.58	53.3	11.4	113.5	6.8										
	10.5	3.2	7.5	41.4	30.2	3.44	53.6	12.0	110.2	6.1										
110	5.3	1.0	2.3	36.3	27.7	4.40	51.9	8.2	129.8	8.9	2.3	0.1	0.2	57.5	3.48	45.6	4.8	70.0	5.9	
	7.9	1.9	4.4	38.1	28.5	4.05	52.5	9.4	123.3	8.2										
	10.5	3.1	7.1	39.0	28.9	3.88	52.7	10.0	120.0	7.5										
120	5.3	0.8	1.9	33.5	26.5	5.01	51.3	6.7	139.6	10.8	1.8	0.1	0.2	57.5	3.48	45.6	4.8	70.0	5.9	
	7.9	1.7	3.9	35.4	27.3	4.60	51.7	7.7	133.1	9.9										
	10.5	2.9	6.6	36.3	27.7	4.41	51.9	8.2	129.9	9.0										

- Interpolation is permissible; extrapolation is not.
- All entering air conditions are 80°F (26.6°C) DB and 67°F (19.4°C) WB in cooling, and 70°F (21°C) DB in heating.
- AHRI/ISO certified conditions are 80.6°F (27°C) DB and 66.2°F (19°C) WB in cooling and 68°F (20°C) DB in heating.
- Table does not reflect fan or pump power corrections for AHRI/ISO conditions.
- All performance is based upon the lower voltage of dual voltage rated units.
- Performance stated is at the rated power supply; performance may vary as the power supply varies from the rated.
- Operation below 40°F (10.0°C) EWT is based upon 20% methanol antifreeze solution.
- Operation below 60°F (15.5°C) EWT requires optional insulated water/refrigerant circuit.
- See performance correction tables for operating conditions other than those listed above.
- See Performance Data Selection Notes for operation in the shaded areas.
- Regular Cooling operation with an EWT of less than 50°F (10.0°C) is not recommended unless variable water flow is available.
- Regular Heating operation with an EWT of more than 90°F (32°C) is not recommended unless variable water flow is available.
- For quiet operation and long term reliability, it is recommended that systems be designed to avoid continuous operation in the outlined areas.
- Performance capacities shown in thousands of Btuh
- Hot Water Generator Capacity is based on 90°F entering water and 0.5 GPM/Ton.

Performance Data SZ*048 EC Blower Motor (Part Load)

Models:
SZ
024-060

1250 CFM Rated Airflow

EWT °F	GPM	WPD		COOLING - EAT 80/67°F							GPM	WPD		HEATING - EAT 70°F						
		PSI	FT	TC	SC	kW	HR	EER	LWT	HWG Cap		PSI	FT	HC	kW	HE	COP	LWT	HWG Cap	
20	Operation Not Recommended										8.5	2.7	6.2	22.0	2.19	14.2	2.9	16.6	2.6	
30	2.9	0.1	0.2	39.5	30.0	1.38	44.2	28.7	60.0	0.7	4.2	0.6	1.5	24.2	2.19	16.4	3.2	22.2	2.4	
											6.3	1.5	3.6	25.2	2.19	17.4	3.4	24.5	2.5	
											8.5	2.5	5.8	25.7	2.20	17.9	3.4	25.8	2.5	
40	4.4	0.7	1.6	38.9	29.7	1.40	43.7	27.8	60.0	0.7	4.2	0.6	1.5	27.9	2.22	20.0	3.7	30.5	2.4	
											6.3	1.4	3.3	29.2	2.23	21.2	3.8	33.3	2.5	
											8.5	2.4	5.5	29.9	2.24	21.9	3.9	34.8	2.6	
50	4.2	0.6	1.5	38.0	29.5	1.56	43.6	24.4	70.7	1.2	4.2	0.6	1.5	31.8	2.27	23.7	4.1	38.7	2.6	
	6.3	1.3	3.1	38.7	29.7	1.42	43.7	27.3	63.9	1.1	6.3	1.3	3.1	33.3	2.29	25.2	4.3	42.0	2.6	
	8.5	2.3	5.2	38.9	29.7	1.35	43.7	28.9	60.3	1.0	8.5	2.3	5.2	34.2	2.30	26.1	4.4	43.8	2.7	
60	4.2	0.7	1.5	36.8	29.0	1.78	43.1	20.7	80.5	1.8	4.2	0.7	1.5	35.7	2.32	27.5	4.5	46.9	2.8	
	6.3	1.2	2.9	37.7	29.4	1.62	43.4	23.2	73.8	1.7	6.3	1.2	2.9	37.6	2.35	29.2	4.7	50.7	2.9	
	8.5	2.2	5.0	38.1	29.5	1.55	43.6	24.6	70.3	1.5	8.5	2.2	5.0	38.6	2.36	30.2	4.8	52.8	3.0	
70	4.2	0.7	1.6	35.1	28.4	2.03	42.3	17.3	90.2	2.6	4.2	0.7	1.6	39.7	2.38	31.2	4.9	55.1	3.2	
	6.3	1.2	2.7	36.3	28.9	1.86	42.9	19.5	83.6	2.4	6.3	1.2	2.7	41.7	2.40	33.2	5.1	59.5	3.2	
	8.5	2.1	4.8	36.8	29.1	1.77	43.1	20.8	80.2	2.2	8.5	2.1	4.8	42.8	2.41	34.2	5.2	61.9	3.3	
80	4.2	0.7	1.6	33.2	27.7	2.30	41.4	14.4	99.7	3.6	4.2	0.7	1.6	43.4	2.41	34.9	5.3	63.4	3.6	
	6.3	1.1	2.6	34.5	28.2	2.11	42.0	16.3	93.3	3.3	6.3	1.1	2.6	45.5	2.42	36.9	5.5	68.3	3.7	
	8.5	2.0	4.6	35.2	28.4	2.02	42.3	17.4	90.0	3.0	8.5	2.0	4.6	46.5	2.42	37.9	5.6	71.0	3.8	
90	4.2	0.7	1.5	31.1	26.7	2.60	40.3	11.9	109.2	4.7	3.8	0.5	1.1	46.3	2.53	37.6	5.4	70.0	4.3	
	6.3	1.1	2.5	32.5	27.4	2.40	41.0	13.5	103.0	4.3										
	8.5	1.9	4.4	33.2	27.6	2.30	41.4	14.4	99.8	3.9										
100	4.2	0.6	1.4	28.8	25.7	2.93	39.2	9.8	118.7	5.9	2.5	0.1	0.2	46.3	2.53	37.6	5.4	70.0	4.3	
	6.3	1.1	2.5	30.2	26.4	2.72	39.9	11.1	112.7	5.4										
	8.5	1.8	4.2	31.0	26.7	2.61	40.3	11.9	109.5	4.9										
110	4.2	0.5	1.2	26.3	24.5	3.30	38.0	8.0	128.1	7.3	1.9	0.1	0.2	46.3	2.53	37.6	5.4	70.0	4.3	
	6.3	1.0	2.4	27.8	25.3	3.07	38.7	9.1	122.3	6.7										
	8.5	1.7	4.0	28.6	25.6	2.96	39.1	9.7	119.3	6.1										
120	4.2	0.4	0.9	23.7	23.2	3.69	36.8	6.4	137.5	8.9	1.5	0.1	0.2	46.3	2.53	37.6	5.4	70.0	4.3	
	6.3	1.0	2.3	25.3	24.0	3.45	37.5	7.3	131.9	8.2										
	8.5	1.7	3.9	26.1	24.4	3.33	37.9	7.8	129.0	7.4										

- Interpolation is permissible; extrapolation is not.
- All entering air conditions are 80°F (26.6°C) DB and 67°F (19.4°C) WB in cooling, and 70°F (21°C) DB in heating.
- AHRI/ISO certified conditions are 80.6°F (27°C) DB and 66.2°F (19°C) WB in cooling and 68°F (20°C) DB in heating.
- Table does not reflect fan or pump power corrections for AHRI/ISO conditions.
- All performance is based upon the lower voltage of dual voltage rated units.
- Performance stated is at the rated power supply; performance may vary as the power supply varies from the rated.
- Operation below 40°F (10.0°C) EWT is based upon 20% methanol antifreeze solution.
- Operation below 60°F (15.5°C) EWT requires optional insulated water/refrigerant circuit.
- See performance correction tables for operating conditions other than those listed above.
- See Performance Data Selection Notes for operation in the shaded areas.
- Regular Cooling operation with an EWT of less than 50°F (10.0°C) is not recommended unless variable water flow is available.
- Regular Heating operation with an EWT of more than 90°F (32°C) is not recommended unless variable water flow is available.
- For quiet operation and long term reliability, it is recommended that systems be designed to avoid continuous operation in the outlined areas.
- Performance capacities shown in thousands of Btuh
- Hot Water Generator Capacity is based on 90°F entering water and 0.5 GPM/Ton.

Performance Data

SZ*048 EC Blower Motor (Full Load)

Models:
SZ
024-060

1550 CFM Rated Airflow

EWT °F	GPM	WPD		COOLING - EAT 80/67°F							GPM	WPD		HEATING - EAT 70°F						
		PSI	FT	TC	SC	kW	HR	EER	LWT	HWG Cap		PSI	FT	HC	kW	HE	COP	LWT	HWG Cap	
20	Operation Not Recommended										12.0	5.2	12.1	33.3	3.03	22.5	3.2	16.2	3.4	
30	4.1	0.2	0.6	53.3	38.3	2.45	61.6	21.7	60.0	1.8	6.0	1.4	3.2	36.5	3.13	25.4	3.4	21.5	3.4	
											9.0	3.0	6.8	37.9	3.17	26.7	3.5	24.1	3.5	
											12.0	4.9	11.3	38.7	3.19	27.4	3.6	25.4	3.6	
40	6.1	1.3	3.0	52.6	38.3	2.38	60.7	22.1	60.0	1.8	6.0	1.3	3.0	41.3	3.26	29.8	3.7	30.1	3.6	
											9.0	2.8	6.4	43.0	3.30	31.3	3.8	33.1	3.7	
											12.0	4.6	10.6	43.9	3.32	32.0	3.9	34.7	3.8	
50	6.0	1.2	2.9	51.6	37.8	2.54	60.6	20.3	70.2	2.4	6.0	1.2	2.9	46.0	3.37	34.0	4.0	38.7	3.9	
	9.0	2.6	6.0	52.3	38.1	2.38	60.7	22.0	63.5	2.2	9.0	2.6	6.0	47.8	3.42	35.7	4.1	42.1	4.0	
	12.0	4.4	10.1	52.6	38.3	2.29	60.7	22.9	60.1	2.0	12.0	4.4	10.1	48.8	3.44	36.6	4.2	43.9	4.1	
60	6.0	1.2	2.7	50.1	37.3	2.77	60.0	18.1	80.0	3.0	6.0	1.2	2.7	50.5	3.48	38.2	4.3	47.3	4.2	
	9.0	2.4	5.6	51.2	37.7	2.61	60.4	19.6	73.4	2.8	9.0	2.4	5.6	52.5	3.52	40.0	4.4	51.1	4.3	
	12.0	4.2	9.6	51.6	37.9	2.53	60.6	20.4	70.1	2.5	12.0	4.2	9.6	53.6	3.55	41.0	4.4	53.2	4.5	
70	6.0	1.1	2.6	48.3	36.7	3.01	59.0	16.0	89.7	3.8	6.0	1.1	2.6	55.0	3.58	42.3	4.5	55.9	4.6	
	9.0	2.3	5.4	49.6	37.1	2.85	59.7	17.4	83.3	3.5	9.0	2.3	5.4	57.3	3.63	44.4	4.6	60.1	4.7	
	12.0	4.0	9.2	50.1	37.3	2.77	60.0	18.1	80.0	3.2	12.0	4.0	9.2	58.5	3.66	45.5	4.7	62.4	4.8	
80	6.0	1.1	2.5	46.2	35.9	3.30	57.9	14.0	99.3	4.8	6.0	1.1	2.4	59.6	3.69	46.5	4.7	64.5	5.0	
	9.0	2.2	5.2	47.6	36.5	3.11	58.6	15.3	93.0	4.4	9.0	2.2	5.2	62.1	3.75	48.8	4.9	69.2	5.1	
	12.0	3.8	8.8	48.3	36.7	3.02	59.0	16.0	89.8	4.0	12.0	3.8	8.8	63.5	3.79	50.1	4.9	71.7	5.2	
90	6.0	1.0	2.4	43.8	35.0	3.66	56.8	12.0	108.9	6.0	4.9	0.5	1.1	62.5	3.91	49.2	4.7	70.0	5.5	
	9.0	2.1	5.0	45.4	35.6	3.42	57.5	13.3	102.8	5.5										
	12.0	3.6	8.4	46.1	35.9	3.31	57.9	13.9	99.6	5.0										
100	6.0	1.0	2.3	41.3	33.8	4.11	55.9	10.1	118.6	7.3	3.3	0.1	0.2	62.5	3.91	49.2	4.7	70.0	5.5	
	9.0	2.1	4.8	42.9	34.5	3.81	56.5	11.3	112.5	6.7										
	12.0	3.5	8.0	43.7	34.9	3.68	56.8	11.9	109.5	6.1										
110	6.0	1.0	2.3	38.7	32.4	4.69	55.4	8.3	128.5	8.8	2.5	0.1	0.2	62.5	3.91	49.2	4.7	70.0	5.5	
	9.0	2.0	4.5	40.3	33.3	4.31	55.7	9.4	122.4	8.1										
	12.0	3.3	7.6	41.2	33.7	4.14	55.9	9.9	119.3	7.4										
120	6.0	1.0	2.3	36.1	30.7	5.43	55.4	6.6	138.5	10.5	2.0	0.1	0.2	62.5	3.91	49.2	4.7	70.0	5.5	
	9.0	1.9	4.3	37.7	31.8	4.95	55.3	7.6	132.3	9.7										
	12.0	3.1	7.1	38.5	32.2	4.74	55.4	8.1	129.2	8.8										

- Interpolation is permissible; extrapolation is not.
- All entering air conditions are 80°F (26.6°C) DB and 67°F (19.4°C) WB in cooling, and 70°F (21°C) DB in heating.
- AHRI/ISO certified conditions are 80.6°F (27°C) DB and 66.2°F (19°C) WB in cooling and 68°F (20°C) DB in heating.
- Table does not reflect fan or pump power corrections for AHRI/ISO conditions.
- All performance is based upon the lower voltage of dual voltage rated units.
- Performance stated is at the rated power supply; performance may vary as the power supply varies from the rated.
- Operation below 40°F (10.0°C) EWT is based upon 20% methanol antifreeze solution.
- Operation below 60°F (15.5°C) EWT requires optional insulated water/refrigerant circuit.
- See performance correction tables for operating conditions other than those listed above.
- See Performance Data Selection Notes for operation in the shaded areas.
- Regular Cooling operation with an EWT of less than 50°F (10.0°C) is not recommended unless variable water flow is available.
- Regular Heating operation with an EWT of more than 90°F (32°C) is not recommended unless variable water flow is available.
- For quiet operation and long term reliability, it is recommended that systems be designed to avoid continuous operation in the outlined areas.
- Performance capacities shown in thousands of Btuh
- Hot Water Generator Capacity is based on 90°F entering water and 0.5 GPM/Ton.

Performance Data

SZ*060 EC Blower Motor (Part Load)

Models:
SZ
024-060

1500 CFM Rated Airflow

EWT °F	GPM	WPD		COOLING - EAT 80/67°F							GPM	WPD		HEATING - EAT 70°F						
		PSI	FT	TC	SC	kW	HR	EER	LWT	HWG Cap		PSI	FT	HC	kW	HE	COP	LWT	HWG Cap	
20	Operation Not Recommended										10.5	4.9	11.3	25.9	2.59	16.6	2.9	16.8	3.4	
30	3.6	0.6	1.3	47.8	34.5	1.65	53.5	29.0	60.0	1.1	5.3	1.6	3.6	28.9	2.63	19.5	3.2	22.6	3.3	
											7.9	2.9	6.6	30.1	2.64	20.7	3.3	24.8	3.4	
											10.5	4.5	10.4	30.7	2.65	21.3	3.4	25.9	3.4	
40	5.3	1.4	3.2	47.4	34.2	1.71	53.3	27.7	60.0	1.1	5.3	1.4	3.3	33.4	2.67	23.9	3.7	30.9	3.4	
											7.9	2.7	6.1	34.8	2.68	25.3	3.8	33.6	3.5	
											10.5	4.2	9.7	35.6	2.69	26.0	3.9	35.0	3.6	
50	5.3	1.3	3.0	46.4	33.9	1.85	53.0	25.0	70.2	1.8	5.3	1.3	3.0	37.8	2.70	28.2	4.1	39.2	3.6	
	7.9	2.5	5.8	47.1	34.1	1.71	53.2	27.5	63.5	1.7	7.9	2.5	5.8	39.5	2.71	29.9	4.3	42.4	3.6	
	10.5	4.0	9.2	47.4	34.2	1.65	53.3	28.8	60.1	1.5	10.5	4.0	9.2	40.4	2.72	30.8	4.4	44.1	3.7	
60	5.3	1.2	2.8	45.0	33.3	2.11	52.5	21.3	80.0	2.5	5.3	1.2	2.8	42.2	2.73	32.5	4.5	47.6	3.8	
	7.9	2.4	5.5	45.9	33.7	1.93	52.8	23.8	73.4	2.3	7.9	2.4	5.5	44.1	2.74	34.4	4.7	51.3	3.9	
	10.5	3.8	8.7	46.4	33.9	1.85	53.0	25.0	70.1	2.1	10.5	3.8	8.7	45.2	2.74	35.4	4.8	53.3	4.0	
70	5.3	1.2	2.7	43.2	32.6	2.41	51.8	18.0	89.7	3.3	5.3	1.2	2.7	46.5	2.75	36.8	5.0	56.0	4.0	
	7.9	2.3	5.2	44.4	33.1	2.20	52.2	20.2	83.3	3.1	7.9	2.3	5.2	48.6	2.76	38.8	5.2	60.1	4.1	
	10.5	3.6	8.4	45.0	33.3	2.11	52.5	21.3	80.0	2.8	10.5	3.6	8.4	49.7	2.76	39.9	5.3	62.4	4.2	
80	5.3	1.1	2.6	41.2	31.7	2.74	50.9	15.0	99.4	4.4	5.3	1.1	2.6	50.7	2.76	40.9	5.4	64.4	4.3	
	7.9	2.2	5.0	42.5	32.3	2.52	51.5	16.9	93.1	4.0	7.9	2.2	5.0	52.8	2.77	43.0	5.6	69.1	4.4	
	10.5	3.5	8.1	43.2	32.6	2.41	51.8	17.9	89.9	3.6	10.5	3.5	8.1	54.0	2.77	44.1	5.7	71.6	4.6	
90	5.3	1.1	2.5	38.8	30.7	3.11	49.9	12.5	109.0	5.6	4.3	0.6	1.4	53.3	2.89	43.5	5.4	70.0	4.8	
	7.9	2.1	4.8	40.4	31.4	2.87	50.6	14.1	102.8	5.1										
	10.5	3.4	7.9	41.1	31.7	2.75	50.9	14.9	99.7	4.7										
100	5.3	1.1	2.4	36.2	29.6	3.51	48.7	10.3	118.5	7.0	2.9	0.1	0.2	53.3	2.89	43.5	5.4	70.0	4.8	
	7.9	2.0	4.7	37.9	30.3	3.26	49.5	11.6	112.6	6.4										
	10.5	3.3	7.6	38.7	30.7	3.13	49.8	12.4	109.5	5.8										
110	5.3	1.0	2.4	33.4	28.4	3.93	47.3	8.5	128.0	8.6	2.2	0.1	0.2	53.3	2.89	43.5	5.4	70.0	4.8	
	7.9	2.0	4.5	35.1	29.1	3.67	48.2	9.6	122.2	7.9										
	10.5	3.2	7.4	36.0	29.5	3.54	48.6	10.2	119.3	7.2										
120	5.3	1.0	2.2	30.3	26.9	4.36	45.8	6.9	137.4	10.4	1.7	0.1	0.2	53.3	2.89	43.5	5.4	70.0	4.8	
	7.9	1.9	4.4	32.1	27.8	4.10	46.7	7.8	131.9	9.5										
	10.5	3.1	7.1	33.1	28.2	3.97	47.2	8.3	129.0	8.6										

- Interpolation is permissible; extrapolation is not.
- All entering air conditions are 80°F (26.6°C) DB and 67°F (19.4°C) WB in cooling, and 70°F (21°C) DB in heating.
- AHRI/ISO certified conditions are 80.6°F (27°C) DB and 66.2°F (19°C) WB in cooling and 68°F (20°C) DB in heating.
- Table does not reflect fan or pump power corrections for AHRI/ISO conditions.
- All performance is based upon the lower voltage of dual voltage rated units.
- Performance stated is at the rated power supply; performance may vary as the power supply varies from the rated.
- Operation below 40°F (10.0°C) EWT is based upon 20% methanol antifreeze solution.
- Operation below 60°F (15.5°C) EWT requires optional insulated water/refrigerant circuit.
- See performance correction tables for operating conditions other than those listed above.
- See Performance Data Selection Notes for operation in the shaded areas.
- Regular Cooling operation with an EWT of less than 50°F (10.0°C) is not recommended unless variable water flow is available.
- Regular Heating operation with an EWT of more than 90°F (32°C) is not recommended unless variable water flow is available.
- For quiet operation and long term reliability, it is recommended that systems be designed to avoid continuous operation in the outlined areas.
- Performance capacities shown in thousands of Btuh
- Hot Water Generator Capacity is based on 90°F entering water and 0.5 GPM/Ton.

Performance Data

SZ*060 EC Blower Motor (Full Load)

Models:
SZ
024-060

1900 CFM Rated Airflow

EWT °F	GPM	WPD		COOLING - EAT 80/67°F							GPM	WPD		HEATING - EAT 70°F						
		PSI	FT	TC	SC	kW	HR	EER	LWT	HWG Cap		PSI	FT	HC	kW	HE	COP	LWT	HWG Cap	
20	Operation Not Recommended										15.0	9.0	20.7	38.8	3.58	26.1	3.2	16.5	4.1	
30	5.0	0.7	1.6	65.3	44.8	2.97	75.4	22.0	60.0	2.5	7.5	2.6	6.1	42.3	3.65	29.3	3.4	22.2	4.2	
											11.3	5.1	11.8	43.8	3.69	30.7	3.5	24.5	4.3	
											15.0	8.2	19.0	44.6	3.70	31.5	3.5	25.8	4.4	
40	7.5	2.3	5.3	64.3	44.4	2.99	74.5	21.5	60.0	2.5	7.5	2.4	5.6	47.9	3.77	34.5	3.7	30.8	4.5	
											11.3	4.8	11.0	49.8	3.81	36.3	3.8	33.6	4.6	
											15.0	7.6	17.6	50.8	3.84	37.2	3.9	35.0	4.7	
50	7.5	2.3	5.2	63.6	44.0	3.11	74.7	20.5	69.9	3.4	7.5	2.3	5.2	53.8	3.90	39.9	4.0	39.3	4.8	
	11.3	4.4	10.3	64.2	44.3	2.94	74.6	21.8	63.3	3.1	11.3	4.4	10.3	56.0	3.95	42.0	4.2	42.5	4.9	
	15.0	7.2	16.5	64.3	44.4	2.87	74.5	22.4	59.9	2.8	15.0	7.2	16.5	57.2	3.98	43.1	4.2	44.3	5.1	
60	7.5	2.1	4.9	62.3	43.5	3.39	74.3	18.4	79.8	4.0	7.5	2.1	4.9	59.8	4.03	45.5	4.3	47.9	5.2	
	11.3	4.2	9.7	63.3	43.9	3.20	74.6	19.8	73.3	3.7	11.3	4.2	9.7	62.4	4.09	47.8	4.5	51.5	5.4	
	15.0	6.8	15.7	63.6	44.0	3.11	74.7	20.5	70.0	3.4	15.0	6.8	15.7	63.7	4.12	49.1	4.5	53.5	5.5	
70	7.5	2.0	4.7	60.3	42.6	3.71	73.5	16.3	89.6	4.9	7.5	2.0	4.7	65.8	4.17	51.0	4.6	56.4	5.7	
	11.3	4.0	9.2	61.7	43.2	3.49	74.1	17.7	83.2	4.5	11.3	4.0	9.2	68.7	4.24	53.6	4.7	60.5	5.8	
	15.0	6.5	15.0	62.3	43.4	3.39	74.3	18.4	79.9	4.1	15.0	6.5	15.0	70.2	4.28	55.0	4.8	62.7	6.0	
80	7.5	2.0	4.5	57.8	41.6	4.08	72.4	14.2	99.3	5.9	7.5	2.0	4.5	71.8	4.32	56.5	4.9	64.9	6.2	
	11.3	3.8	8.8	59.5	42.3	3.83	73.1	15.5	93.0	5.5	11.3	3.8	8.8	74.9	4.40	59.3	5.0	69.5	6.4	
	15.0	6.3	14.5	60.3	42.6	3.72	73.5	16.2	89.8	5.0	15.0	6.3	14.4	76.5	4.44	60.8	5.1	71.9	6.6	
90	7.5	1.9	4.3	55.0	40.4	4.51	71.0	12.2	108.9	7.2	6.0	0.9	2.2	75.3	4.59	59.7	4.8	70.0	7.0	
	11.3	3.7	8.5	56.9	41.2	4.23	71.9	13.4	102.8	6.6										
	15.0	6.1	14.0	57.8	41.6	4.10	72.3	14.1	99.6	6.0										
100	7.5	1.8	4.2	51.8	39.1	5.01	69.6	10.3	118.6	8.8	4.0	0.1	0.2	75.3	4.59	59.7	4.8	70.0	7.0	
	11.3	3.6	8.2	53.8	39.9	4.69	70.5	11.5	112.5	8.0										
	15.0	5.9	13.5	54.8	40.3	4.54	71.0	12.1	109.5	7.3										
110	7.5	1.7	4.0	48.4	37.6	5.59	68.3	8.7	128.2	10.5	3.0	0.1	0.2	75.3	4.59	59.7	4.8	70.0	7.0	
	11.3	3.4	7.9	50.5	38.5	5.22	69.1	9.7	122.3	9.6										
	15.0	5.6	13.0	51.6	39.0	5.05	69.5	10.2	119.3	8.8										
120	7.5	1.6	3.8	44.9	35.9	6.25	67.1	7.2	137.9	12.5	2.4	0.1	0.2	75.3	4.59	59.7	4.8	70.0	7.0	
	11.3	3.3	7.5	47.0	36.9	5.84	67.8	8.1	132.1	11.5										
	15.0	5.4	12.5	48.1	37.4	5.64	68.2	8.5	129.1	10.4										

- Interpolation is permissible; extrapolation is not.
- All entering air conditions are 80°F (26.6°C) DB and 67°F (19.4°C) WB in cooling, and 70°F (21°C) DB in heating.
- AHRI/ISO certified conditions are 80.6°F (27°C) DB and 66.2°F (19°C) WB in cooling and 68°F (20°C) DB in heating.
- Table does not reflect fan or pump power corrections for AHRI/ISO conditions.
- All performance is based upon the lower voltage of dual voltage rated units.
- Performance stated is at the rated power supply; performance may vary as the power supply varies from the rated.
- Operation below 40°F (10.0°C) EWT is based upon 20% methanol antifreeze solution.
- Operation below 60°F (15.5°C) EWT requires optional insulated water/refrigerant circuit.
- See performance correction tables for operating conditions other than those listed above.
- See Performance Data Selection Notes for operation in the shaded areas.
- Regular Cooling operation with an EWT of less than 50°F (10.0°C) is not recommended unless variable water flow is available.
- Regular Heating operation with an EWT of more than 90°F (32°C) is not recommended unless variable water flow is available.
- For quiet operation and long term reliability, it is recommended that systems be designed to avoid continuous operation in the outlined areas.
- Performance capacities shown in thousands of Btuh
- Hot Water Generator Capacity is based on 90°F entering water and 0.5 GPM/Ton.

Blower Performance: CV EC Standard Unit

Models:
SZ
024-060

CV EC MOTOR ADVANTAGE

A major benefit of the CV EC motor over other blower motor types is its ability to adjust airflow remotely through the iGate 2 web portal/mobile app or directly at the unit with the Wireless Service Tool. Airflow levels can be adjusted in increments of 25 CFM from the unit's minimum and maximum CFM range (see the Blower Performance: CV EC Blower Motor Standard Unit table for details).

Blower Performance: CV EC Blower Motor Standard Unit

Model	Max ESP (in wg)	Fan Motor (hp)	Range	Cooling Mode		Heating Mode		Dehumid Mode		Fan Only Mode	Aux Emergency Mode
				Stage 2	Stage 1	Stage 2	Stage 1	Stage 2	Stage 1		
SZ024	0.75	1/2	Minimum	600	450	600	450	600	450	300	600
			Default	750	600	750	600	650	500	350	750
			Maximum	850	650	850	650	800	600	850	850
SZ030	0.5	1/2	Minimum	750	550	750	550	750	550	375	750
			Default	925	750	925	750	800	625	425	925
			Maximum	1,050	800	1,050	800	1,000	750	1,050	1,050
SZ036	0.6	3/4	Minimum	900	675	900	675	900	675	450	900
			Default	1,125	900	1,125	900	975	750	525	1,125
			Maximum	1,275	975	1,275	975	1,200	900	1,275	1,275
SZ042	0.6	3/4	Minimum	1,050	775	1,050	775	1,050	775	525	1,050
			Default	1,300	1,050	1,300	1,050	1,125	875	600	1,300
			Maximum	1,475	1,125	1,475	1,125	1,400	1,050	1,475	1,475
SZ048	0.6	3/4	Minimum	1,200	900	1,200	900	1,200	900	600	1,200
			Default	1,500	1,200	1,500	1,200	1,300	1,000	700	1,500
			Maximum	1,700	1,300	1,700	1,300	1,600	1,200	1,700	1,700
SZ060	0.75	1	Minimum	1,500	1,125	1,500	1,125	1,500	1,125	750	1,500
			Default	1,875	1,500	1,875	1,500	1,625	1,250	875	1,875
			Maximum	2,125	1,625	2,125	1,625	2,000	1,500	2,125	2,125

- Blower performance data is based on the lowest nameplate voltage setting.
- Blower performance is based on a wet coil with clean 1-inch filter.
- Blower performance is based on operating conditions of 80°F DB and 67°F WB.
- CFM Tolerance is ±7%
- The maximum allowable altitude of installation for this product is 6,561 ft (2,000 m).

Electrical Data: CV EC Blower Motor

Models:
SZ
024-060

Units with HWG and Pump (no Internal Flow Controller)

Model	Voltage Code	Voltage	Voltage Min/Max	Compressor				Fan Motor FLA	Pump	Total Unit FLA	Min Circ Amp	Fuse HACR
				MCC	RLA	LRA	Qty		HWG FLA			
SZ*024	G.J.	208/230-1-60	187/252	16.0	10.3	62.0	1	4.2	0.28	14.7	17.3	25
SZ*030	G.J.	208/230-1-60	187/252	22.7	14.6	82.0	1	4.2	0.28	19.0	22.7	35
SZ*036	G.J.	208/230-1-60	187/252	22.7	14.6	76.0	1	5.9	0.28	20.7	24.4	35
SZ*042	G.J.	208/230-1-60	187/252	28.4	18.2	106.0	1	5.9	0.28	24.4	28.9	45
SZ*048	G.J.	208/230-1-60	187/252	28.6	18.3	138.0	1	5.9	0.28	24.5	29.1	45
SZ*060	J.	208/230-1-60	187/252	34.8	22.3	149.0	1	7.5	0.28	30.1	35.7	50

Units with Internal Flow Controller and HWG with Pump - Standard Head Variable Pump

Model	Voltage Code	Voltage	Voltage Min/Max	Compressor				Fan Motor FLA	Pump		Total Unit FLA	Min Circ Amp	Fuse HACR
				MCC	RLA	LRA	Qty		Motor FLA	HWG FLA			
SZ*024	G.J.	208/230-1-60	187/252	16.0	10.3	62.0	1	4.2	0.64	0.28	15.4	17.9	25
SZ*030	G.J.	208/230-1-60	187/252	22.7	14.6	82.0	1	4.2	0.64	0.28	19.7	23.3	35
SZ*036	G.J.	208/230-1-60	187/252	22.7	14.6	76.0	1	5.9	0.64	0.28	21.4	25.0	35
SZ*042	G.J.	208/230-1-60	187/252	28.4	18.2	106.0	1	5.9	0.64	0.28	25.0	29.6	45
SZ*048	G.J.	208/230-1-60	187/252	28.6	18.3	138.0	1	5.9	0.64	0.28	25.2	29.7	45
SZ*060	J.	208/230-1-60	187/252	34.8	22.3	149.0	1	7.5	0.64	0.28	30.7	36.3	50

Units with Internal Flow Controller and HWG with Pump - High Head Variable Pump

Model	Voltage Code	Voltage	Voltage Min/Max	Compressor				Fan Motor FLA	Pump		Total Unit FLA	Min Circ Amp	Fuse HACR
				MCC	RLA	LRA	Qty		Motor FLA	HWG FLA			
SZ*024	G.J.	208/230-1-60	187/252	16.0	10.3	62.0	1	4.2	1.44	0.28	16.2	18.7	25
SZ*030	G.J.	208/230-1-60	187/252	22.7	14.6	82.0	1	4.2	1.44	0.28	20.5	24.1	35
SZ*036	G.J.	208/230-1-60	187/252	22.7	14.6	76.0	1	5.9	1.44	0.28	22.2	25.8	40
SZ*042	G.J.	208/230-1-60	187/252	28.4	18.2	106.0	1	5.9	1.44	0.28	25.8	30.4	45
SZ*048	G.J.	208/230-1-60	187/252	28.6	18.3	138.0	1	5.9	1.44	0.28	26.0	30.5	45
SZ*060	J.	208/230-1-60	187/252	34.8	22.3	149.0	1	7.5	1.44	0.28	31.5	37.1	50

ClimateMaster works continually to improve its products. As a result, the design and specifications of each product at the time of order may be changed without notice and may not be as described herein. Please contact ClimateMaster's Customer Service Department at 800-299-9747 for specific information on the current design and specifications. Statements and other information contained herein are not express warranties and do not form the basis of any bargain between the parties, but are merely ClimateMaster's opinion or commendation of its products. The latest version of this document is available at www.climatemaster.com. Engineered and assembled in the USA. © ClimateMaster, Inc. All Rights Reserved 2024

Part Load Performance: Correction Tables

Models:
SZ
024-060

Cooling Correction

Entering Air WB °F	Total Capacity	Sensible Cooling Capacity Multipliers - Entering DB °F						Power	Heat of Rejection
		65	70	75	80	85	90		
50	0.708	1.115	*	*	*	*	*	1.015	0.783
55	0.794	0.893	1.105	*	*	*	*	1.011	0.847
60	0.880	0.671	0.883	*	*	*	*	1.006	0.911
65	0.966		0.662	0.868	1.088	1.279	*	1.002	0.975
67	1.000		0.574	0.779	1.000	1.190	1.396	1.000	1.000
70	1.051			0.646	0.868	1.057	1.263	0.997	1.038
75	1.137				0.648	0.835	1.041	0.993	1.102

Notes:

- AHRI/ISO/ASHRAE 13256-1 uses entering air conditions of Cooling - 80.6°F (27°C) DB/ 66.2°F (19°C) WB, and Heating 68°F (20°C) DB/ 59°F (15°C) WB entering air temperature.
- Asterisks indicate that no correction factor is needed, Total Capacity equals Sensible capacity.
- Entering DB temperature range is based on operating limits, not on commission limits.
- Cooling and heating air corrections based on rated airflow.

Entering Air Heating Correction

Entering Air WB °F	Heating Capacity	Power	Heat of Rejection
50	1.020	0.763	1.102
55	1.015	0.822	1.076
60	1.010	0.882	1.051
65	1.005	0.941	1.025
70	1.000	1.000	1.000
75	0.995	1.059	0.975
80	0.990	1.118	0.949

Airflow Correction

% of Rated	Heating			Cooling				
	Heating Capacity	Power	Heat of Extraction	Total Capacity	Sensible Capacity	S/T	Power	Heat of Rejection
80	0.969	1.009	0.974	0.979	0.905	0.924	0.947	0.979
85	0.977	1.007	0.980	0.984	0.929	0.944	0.961	0.984
90	0.984	1.005	0.987	0.989	0.952	0.963	0.974	0.989
95	0.992	1.002	0.993	0.995	0.976	0.981	0.987	0.995
100	1.000	1.000	1.000	1.000	1.000	1.000	1.000	1.000
105	1.008	0.998	1.007	1.005	1.024	1.018	1.013	1.005
110	1.016	0.995	1.013	1.011	1.048	1.037	1.026	1.011

ClimateMaster works continually to improve its products. As a result, the design and specifications of each product at the time of order may be changed without notice and may not be as described herein. Please contact ClimateMaster's Customer Service Department at 800-299-9747 for specific information on the current design and specifications. Statements and other information contained herein are not express warranties and do not form the basis of any bargain between the parties, but are merely ClimateMaster's opinion or commendation of its products. The latest version of this document is available at www.climatemaster.com. Engineered and assembled in the USA. © ClimateMaster, Inc. All Rights Reserved 2024

Full Load Performance: Correction Tables

Models:
SZ
024-060

Cooling Correction

Entering Air WB °F	Total Capacity	Sensible Cooling Capacity Multipliers - Entering DB °F						Power	Heat of Rejection
		65	70	75	80	85	90		
50	0.730	1.137	*	*	*	*	*	0.944	0.786
55	0.809	0.913	1.117	*	*	*	*	0.960	0.849
60	0.889	0.689	0.894	*	*	*	*	0.977	0.912
65	0.968		0.672	0.877	1.087	1.287	*	0.993	0.975
67	1.000		0.583	0.788	1.000	1.199	1.404	1.000	1.000
70	1.048			0.655	0.869	1.067	1.272	1.010	1.038
75	1.127				0.650	0.847	1.053	1.027	1.101

Notes:

- AHRI/ISO/ASHRAE 13256-1 uses entering air conditions of Cooling - 80.6°F (27°C) DB/ 66.2°F (19°C) WB, and Heating 68°F (20°C) DB/ 59°F (15°C) WB entering air temperature.
- Asterisks indicate that no correction factor is needed, Total Capacity equals Sensible capacity.
- Entering DB temperature range is based on operating limits, not on commission limits.
- Cooling and heating air corrections based on rated airflow.

Entering Air Heating Correction

Entering Air WB °F	Heating Capacity	Power	Heat of Rejection
50	1.026	0.807	1.103
55	1.019	0.855	1.077
60	1.013	0.904	1.052
65	1.006	0.952	1.026
70	1.000	1.000	1.000
75	0.994	1.048	0.974
80	0.987	1.096	0.948

Airflow Correction


% of Rated	Heating			Cooling				
	Heating Capacity	Power	Heat of Extraction	Total Capacity	Sensible Capacity	S/T	Power	Heat of Rejection
80	0.963	1.008	0.965	0.975	0.913	0.936	0.937	0.974
85	0.972	1.006	0.974	0.981	0.935	0.952	0.952	0.980
90	0.981	1.004	0.983	0.988	0.956	0.968	0.968	0.987
95	0.991	1.002	0.991	0.994	0.978	0.984	0.984	0.993
100	1.000	1.000	1.000	1.000	1.000	1.000	1.000	1.000
105	1.009	0.998	1.009	1.006	1.022	1.015	1.016	1.007
110	1.019	0.996	1.017	1.012	1.044	1.031	1.032	1.013

ClimateMaster works continually to improve its products. As a result, the design and specifications of each product at the time of order may be changed without notice and may not be as described herein. Please contact ClimateMaster's Customer Service Department at 800-299-9747 for specific information on the current design and specifications. Statements and other information contained herein are not express warranties and do not form the basis of any bargain between the parties, but are merely ClimateMaster's opinion or commendation of its products. The latest version of this document is available at www.climatemaster.com. Engineered and assembled in the USA. © ClimateMaster, Inc. All Rights Reserved 2024


High Head and Standard Variable Pump Performance

Models:
SZ
024-060

Standard Head Variable Pump Performance



High Head Variable Pump Performance



Antifreeze Correction Table

Models:
SZ
024-060

EWT (°F)	Antifreeze Type	Antifreeze %	Cooling			Heating		WPD
			Total Cap	Sensible Cap	Watts	Total Cap	Watts	
90	Water	0%	1.000	1.000	1.000	1.000	1.000	1.000
	Ethanol	5%	0.998	0.998	1.002	0.996	0.999	1.025
		10%	0.996	0.996	1.003	0.991	0.997	1.048
		15%	0.994	0.994	1.005	0.987	0.996	1.098
		20%	0.991	0.991	1.006	0.982	0.994	1.142
		25%	0.986	0.986	1.009	0.972	0.991	1.207
		30%	0.981	0.981	1.012	0.962	0.988	1.265
		35%	0.977	0.977	1.015	0.953	0.985	1.312
		40%	0.972	0.972	1.018	0.943	0.982	1.370
		45%	0.966	0.966	1.023	0.931	0.978	1.431
		50%	0.959	0.959	1.027	0.918	0.974	1.494
	Ethylene Glycol	5%	0.998	0.998	1.002	0.996	0.999	1.021
		10%	0.996	0.996	1.003	0.991	0.997	1.040
		15%	0.994	0.994	1.004	0.987	0.996	1.079
		20%	0.991	0.991	1.005	0.982	0.995	1.114
		25%	0.988	0.988	1.008	0.976	0.993	1.146
		30%	0.985	0.985	1.010	0.969	0.990	1.175
		35%	0.982	0.982	1.012	0.963	0.988	1.208
		40%	0.979	0.979	1.014	0.956	0.986	1.243
		45%	0.976	0.976	1.016	0.950	0.984	1.278
		50%	0.972	0.972	1.018	0.943	0.982	1.314
	Methanol	5%	0.997	0.997	1.002	0.993	0.998	1.039
		10%	0.993	0.993	1.004	0.986	0.996	1.075
		15%	0.990	0.990	1.007	0.979	0.994	1.116
		20%	0.986	0.986	1.009	0.972	0.991	1.154
		25%	0.982	0.982	1.012	0.964	0.989	1.189
		30%	0.978	0.978	1.014	0.955	0.986	1.221
		35%	0.974	0.974	1.017	0.947	0.984	1.267
		40%	0.970	0.970	1.020	0.939	0.981	1.310
		45%	0.966	0.966	1.023	0.930	0.978	1.353
		50%	0.961	0.961	1.026	0.920	0.975	1.398
	Propylene Glycol	5%	0.995	0.995	1.003	0.990	0.997	1.065
		10%	0.990	0.990	1.006	0.980	0.994	1.119
		15%	0.986	0.986	1.009	0.971	0.991	1.152
		20%	0.981	0.981	1.012	0.962	0.988	1.182
		25%	0.978	0.978	1.014	0.956	0.986	1.227
		30%	0.975	0.975	1.016	0.950	0.984	1.267
		35%	0.972	0.972	1.018	0.944	0.982	1.312
		40%	0.969	0.969	1.020	0.938	0.980	1.356
		45%	0.965	0.965	1.023	0.929	0.977	1.402
		50%	0.960	0.960	1.026	0.919	0.974	1.450

Table continued on next page

Antifreeze Correction Table

Models:
SZ
024-060

Table continued from previous page

EWT (°F)	Antifreeze Type	Antifreeze %	Cooling			Heating		WPD
			Total Cap	Sensible Cap	Watts	Total Cap	Watts	
30	Water	0%	1.000	1.000	1.000	1.000	1.000	1.000
	Ethanol	5%	0.991	0.991	1.006	0.981	0.994	1.140
		10%	0.981	0.981	1.012	0.961	0.988	1.242
		15%	0.973	0.973	1.018	0.944	0.983	1.295
		20%	0.964	0.964	1.024	0.927	0.977	1.343
		25%	0.959	0.959	1.028	0.917	0.974	1.363
		30%	0.954	0.954	1.031	0.907	0.970	1.383
		35%	0.949	0.949	1.035	0.897	0.967	1.468
		40%	0.944	0.944	1.038	0.887	0.964	1.523
		45%	0.940	0.940	1.041	0.880	0.962	1.580
		50%	0.936	0.936	1.043	0.872	0.959	1.639
	Ethylene Glycol	5%	0.997	0.997	1.002	0.993	0.998	1.040
		10%	0.993	0.993	1.004	0.986	0.996	1.075
		15%	0.990	0.990	1.006	0.980	0.994	1.122
		20%	0.987	0.987	1.008	0.973	0.992	1.163
		25%	0.983	0.983	1.011	0.966	0.990	1.195
		30%	0.979	0.979	1.013	0.958	0.987	1.225
		35%	0.976	0.976	1.016	0.951	0.985	1.279
		40%	0.972	0.972	1.018	0.943	0.982	1.324
		45%	0.969	0.969	1.021	0.937	0.980	1.371
		50%	0.966	0.966	1.023	0.930	0.978	1.419
	Methanol	5%	0.995	0.995	1.004	0.989	0.997	1.069
		10%	0.989	0.989	1.007	0.978	0.993	1.127
		15%	0.984	0.984	1.011	0.968	0.990	1.164
		20%	0.979	0.979	1.014	0.957	0.986	1.197
		25%	0.975	0.975	1.017	0.949	0.984	1.216
		30%	0.971	0.971	1.019	0.941	0.981	1.235
		35%	0.967	0.967	1.022	0.933	0.979	1.286
		40%	0.963	0.963	1.025	0.924	0.976	1.323
		45%	0.959	0.959	1.028	0.917	0.974	1.360
		50%	0.955	0.955	1.030	0.910	0.971	1.399
	Propylene Glycol	5%	0.995	0.995	1.004	0.989	0.997	1.071
		10%	0.989	0.989	1.007	0.978	0.993	1.130
		15%	0.985	0.985	1.010	0.968	0.990	1.206
		20%	0.980	0.980	1.013	0.958	0.987	1.270
		25%	0.974	0.974	1.017	0.947	0.983	1.359
		30%	0.968	0.968	1.021	0.935	0.979	1.433
		35%	0.963	0.963	1.025	0.924	0.976	1.522
		40%	0.957	0.957	1.029	0.913	0.972	1.614
		45%	0.949	0.949	1.034	0.898	0.967	1.712
		50%	0.941	0.941	1.039	0.882	0.962	1.816

ClimateMaster works continually to improve its products. As a result, the design and specifications of each product at the time of order may be changed without notice and may not be as described herein. Please contact ClimateMaster's Customer Service Department at 800-299-9747 for specific information on the current design and specifications. Statements and other information contained herein are not express warranties and do not form the basis of any bargain between the parties, but are merely ClimateMaster's opinion or commendation of its products. The latest version of this document is available at www.climatemaster.com. Engineered and assembled in the USA. © ClimateMaster, Inc. All Rights Reserved 2024

Water Pressure Drop Adder for Options: Correction Tables

Models:
SZ
024-060

System Pressure Drop Valve

Model	GPM	Low System Pressure Drop Valve (Adders)					High System Pressure Drop Valve (Adders)				
		CV	Close Off	MOPD	PSI	FT	CV	Close Off	MOPD	PSI	FT
SZ024	6	4.7	200	30	1.63	3.76	4.7	200	30	0.64	1.48
	4.5				0.92	2.12				0.20	0.47
	3				0.41	0.94				0.04	0.09
SZ030	7.5	7.4	200	30	1.03	2.37	4.7	200	30	0.25	0.59
	5.6				0.57	1.32				0.08	0.18
	3.8				0.26	0.61				0.02	0.04
SZ036	9	7.4	200	30	1.48	3.42	4.7	200	30	0.53	1.22
	6.8				0.84	1.95				0.17	0.40
	4.5				0.37	0.85				0.03	0.08
SZ042	10.5	10	200	30	1.10	2.55	4.7	200	30	0.29	0.68
	7.9				0.62	1.44				0.09	0.22
	5.2				0.27	0.62				0.02	0.04
SZ048	12	10	200	30	1.44	3.33	4.7	200	30	0.50	1.16
	9				0.81	1.87				0.16	0.37
	6				0.36	0.83				0.03	0.07
SZ060	15	19	200	30	0.62	1.44	7.4	200	30	0.04	0.09
	11.3				0.35	0.82				0.01	0.03
	7.5				0.16	0.36				0.00	0.01

Tranquility (SZ) Series

Unit Size	024	030	036	042	048	060
Compressor (1 Each)	Scroll					
Number of refrigerant circuits	1	1	1	1	1	1
Factory Charge R-454B (oz)	40	36	46	56	56	69
Refrigerant Leak Detection System	O	O	O	O	O	R
Number of Sensors	2	2	2	2	2	2
Water Connection Size						
Swivel	1"	1"	1"	1"	1"	1"
System Water Volume (gal) ¹	0.323	0.323	0.738	0.890	0.890	0.939
Vertical						
Filter Standard - 1" Throwaway (inch)	20x20	20x20	24x24	24x24	28x28	28x28
Weight - Operating (lbs.)	216	224	245	260	315	330
Weight - Packaged (lbs.)	221	229	251	266	322	337
Horizontal						
Filter Standard - 1" Throwaway	18x24	18x24	2-14x20	2-14x20	1-20x24 1-14x20	1-20x24 1-14x20
Weight - Operating (lbs.)	208	208	233	244	299	314
Weight - Packaged (lbs.)	213	213	239	250	306	321
Hot Water Generator						
Swivel - Residential Class	1"	1"	1"	1"	1"	1"
Weight - HWG Adder (lbs.)	+15	+15	+15	+15	+15	+15

Notes:

- All dimensions displayed above are in inches unless otherwise marked.
- The standard Condensate Drain Connection is rubber coupling that couples to ¾-inch schedule 40/80 PVC.
- The optional Stainless Steel Condensate Drain Connection is ¾-inch FPT.
- FPT = Female Pipe Thread.
- O = Optional, R = Required
- 1. Volume without water options.



Unit Maximum Water Working Pressure

Options	Max Pressure PSIG [kPa]
Base Unit	300 [2,068]
Internal Modulating Valve	300 [2,068]

Horizontal Dimensional Data



Models:
SZ
024-060

LEFT RETURN




Note: Blower service panel requires 2-foot service access


RIGHT RETURN




RIGHT RETURN BACK DISCHARGE




LEFT RETURN STRAIGHT DISCHARGE



RIGHT RETURN STRAIGHT DISCHARGE



LEFT RETURN LEFT VIEW AIR COIL OPENING



RIGHT RETURN RIGHT VIEW AIR COIL OPENING

Notes:

1. While clear access to all removable panels is not required, installer should take care to comply with all building codes and allow adequate clearance for future field service.
2. Units come standard with air-filter rails. For duct connections, order optional filter frames. See product options decoder for details. You can convert filter rails in the field with an accessory air-filter-frame kit. Please see the accessory submittal for details.
3. Discharge flange and hanger brackets are factory installed.
4. Condensate connection is 3/4-inch MPT.
5. Blower service panel requires 2-foot service access.
6. Blower service access is through back panel on straight-discharge units or through panel opposite air coil on back-discharge units.
7. Water connections for optional hot water generator are 1-inch swivels.
8. OSP are removable panels that provide additional access to the units interior. Clear access to OSP panels is not required and they are not to be used in place of the mandatory CCP and BSP panels.

Legend:


CCP = Control/Compressor Access
BSP = Blower Service Panel
OSP = Optional Service Panel (not required)

ClimateMaster works continually to improve its products. As a result, the design and specifications of each product at the time of order may be changed without notice and may not be as described herein. Please contact ClimateMaster's Customer Service Department at 800-299-9747 for specific information on the current design and specifications. Statements and other information contained herein are not express warranties and do not form the basis of any bargain between the parties, but are merely ClimateMaster's opinion or commendation of its products. The latest version of this document is available at www.climatemaster.com. Engineered and assembled in the USA. © ClimateMaster, Inc. All Rights Reserved 2024


Horizontal Service Access

Models:
SZ
024-060


LEFT RETURN BACK DISCHARGE




RIGHT RETURN BACK DISCHARGE



LEFT RETURN STRAIGHT DISCHARGE



RIGHT RETURN STRAIGHT DISCHARGE



Notes:

1. While clear access to all removable panels is not required, installer should take care to comply with all building codes and allow adequate clearance for future field service.
2. CCP and BSP requires 2-feet of service access.
3. Blower service access is through back panel on straight discharge units or through panel opposite air coil on back discharge units.
4. OSP are removable panels that provide additional access to the units interior. Clear access to OSP panels is not required and they are not to be used in place of the mandatory CCP and BSP panels.

 = Mandatory Service Access 2-foot (61 cm)

 = Optional Service Access 2-foot (61 cm)

Legend:

CCP = Control/Compressor Access


BSP = Blower Service Panel

OSP = Optional Service Panel (not required)

ClimateMaster works continually to improve its products. As a result, the design and specifications of each product at the time of order may be changed without notice and may not be as described herein. Please contact ClimateMaster's Customer Service Department at 800-299-9747 for specific information on the current design and specifications. Statements and other information contained herein are not express warranties and do not form the basis of any bargain between the parties, but are merely ClimateMaster's opinion or commendation of its products. The latest version of this document is available at www.climatemaster.com. Engineered and assembled in the USA. © ClimateMaster, Inc. All Rights Reserved 2024

Vertical Upflow Dimensional Data

Models:
SZ
024-060



Notes:


1. While clear access to all removable panels is not required, installer should take care to comply with all building codes and allow adequate clearance for future field service.
2. Front and Side access is preferred for service access. However, all components may be serviced from the front access panel if side access is not available.
3. Discharge flange is field installed.
4. Condensate connection is 3/4-inch MPT.
5. Water connections for optional hot water generator are 1-inch swivels.
6. Units come standard with air filter rails. For duct connections, optional filter frames should be ordered. See product options decoder for details. Filter rails can be converted in the field with an accessory air filter frame kit. Please see the accessory submittal for details.

Legend:


CCP = Control/Compressor Access
BSP = Blower Service Panel
OSP = Optional Service Panel (not required)

ClimateMaster works continually to improve its products. As a result, the design and specifications of each product at the time of order may be changed without notice and may not be as described herein. Please contact ClimateMaster's Customer Service Department at 800-299-9747 for specific information on the current design and specifications. Statements and other information contained herein are not express warranties and do not form the basis of any bargain between the parties, but are merely ClimateMaster's opinion or commendation of its products. The latest version of this document is available at www.climatemaster.com. Engineered and assembled in the USA. © ClimateMaster, Inc. All Rights Reserved 2024

LEFT RETURN



RIGHT RETURN



Notes:

1. While clear access to all removable panels is not required, installer should take care to comply with all building codes and allow adequate clearance for future field service.
2. Front and side access is preferred for service access. However, all components may be serviced from the front access panel if side access is not available.
3. OSP are removable panels that provide additional access to the units interior. Clear access to OSP panels is not required and they are not to be used in place of the mandatory CCP and BSP panels.
4. Top supply air is shown, the same clearances apply to bottom supply air units.

-  = Mandatory Service Access 2-foot (61 cm)
-  = Optional Service Access 2-foot (61 cm)

Legend:

- CCP = Control/Compressor Access
BSP = Blower Service Panel
OSP = Optional Service Panel (not required)

Dimensional Data

Models:
SZ
024-060

Cabinet Dimensions (inch)

Model	Cabinet Config	Depth/Length	Width	Height
		A	B	C
SZ024-030	H	48.4	22.5	18.3
	V	22.5	22.5	40.0
SZ036-042	H	53.3	22.5	21.0
	V	26.0	22.5	45.0
SZ048-060	H	68.0	25.5	21.0
	V	29.3	25.5	50.5

Electrical Knockouts (inch)

Model	Cabinet Config	H	Low Voltage	High Voltage	G
			J KO 1/2"	K KO 3/4"	
SZ024-030	H	4.1	7.1	14.8	1.3
	V	4.1	6.7	14.8	1.3
SZ036-042	H	4.1	7.1	15.8	1.3
	V	4.1	7.1	15.8	1.3
SZ048-060	H	4.1	7.1	16.7	1.3
	V	4.1	7.1	16.7	1.3

Shipping Dimensions and Water Connections (inch)

Model	Cabinet Config	Shipping Dimensions			Water Connections										Condensate Drain Pan		
		Depth/Length	Width	Height	Water In		Water Out		Water In/Out		HWG In		HWG Out		AA	BB	Condensate Drain Pan Fitting ³
		A	B	C	D	E	F	E	Com ¹	Res ²	DD	EE	FF	EE			
SZ024-030	H	53.5	28.4	24.3	3.7	2.0	9.8	2.0	3/4"	1"	13.1	1.6	15.8	1.6	3.4	0.8	3/4" MPT
	V	27.3	27.3	46.0	3.7	2.0	9.8	2.0	3/4"	1"	13.1	1.6	15.8	1.6	1.4	19.7	3/4" MPT
SZ036-042	H	58.5	28.4	27.0	3.7	2.0	11.1	2.0	3/4"	1"	14.8	1.6	17.6	1.6	3.4	0.8	3/4" MPT
	V	31.0	28.0	51.0	3.7	2.0	11.1	2.0	3/4"	1"	14.8	1.6	17.6	1.6	1.4	20.7	3/4" MPT
SZ048-060	H	74.5	31.4	27.0	3.7	2.0	11.1	2.0	1"	1"	15.8	1.6	18.5	1.6	3.4	0.8	3/4" MPT
	V	36.0	31.0	56.5	3.7	2.0	11.1	2.0	1"	1"	15.8	1.6	18.5	1.6	1.4	22.2	3/4" MPT

Notes:

1. Commercial water connections are Female Pipe Thread (FPT) fittings
2. Residential water connections are 1-inch swivel connections
3. See PDF drawings for reference

Discharge and Return Connections (inch)

Model	Cabinet Config	Discharge Connection Duct Flange Installed				Return Connection Using Return Air Opening			
		Supply Height	Supply Width	O	P	Return Width	Return Height	S	T
		M	N			Q	R		
SZ024-030	H	13.1	9.6	3.9	1.2	22.9	16.3	1.2	1.0
	V	14.0	14.0	7.5	4.2	18.4	18.2	1.7	1.0
SZ036-042	H	16.0	11.0	2.9	2.5	26.1	19.0	1.2	1.0
	V	14.0	14.0	7.5	6.0	22.9	22.2	0.8	1.0
SZ048	H	15.9	13.5	4.1	1.2	36.1	19.0	1.2	1.0
	V	18.0	16.0	8.5	5.7	26.2	26.2	0.8	1.0
SZ060	H	18.0	13.3	4.2	1.1	36.1	19.0	1.2	1.0
	V	18.0	16.0	8.5	5.7	26.2	26.2	0.8	1.0

Hanger Dimensions (inch)

Model	Cabinet Config	Unit Hanger Detail		
		U	V	W
SZ024-030	H	48.1	24.6	20.3
SZ036-042	H	53.1	24.6	20.3
SZ048-060	H	67.8	27.6	23.3

ClimateMaster works continually to improve its products. As a result, the design and specifications of each product at the time of order may be changed without notice and may not be as described herein. Please contact ClimateMaster's Customer Service Department at 800-299-9747 for specific information on the current design and specifications. Statements and other information contained herein are not express warranties and do not form the basis of any bargain between the parties, but are merely ClimateMaster's opinion or commendation of its products. The latest version of this document is available at www.climatemaster.com. Engineered and assembled in the USA. © ClimateMaster, Inc. All Rights Reserved 2024

Dimensional Data

Models:
SZ
024-060

Cabinet Dimensions (cm)

Model	Cabinet Config	Depth/Length	Width	Height
		A	B	C
SZ024-030	H	123.0	57.0	46.4
	V	57.0	57.1	101.6
SZ036-042	H	135.4	57.0	53.3
	V	66.2	57.1	114.3
SZ048-060	H	172.8	64.7	53.3
	V	74.4	64.7	128.3

Electrical Knockouts (cm)

Model	Cabinet Config	H	Low Voltage	High Voltage	G
			J KO 1/2"	K KO 3/4"	
SZ024-030	H	10.5	18.1	37.5	3.2
	V	10.5	17.0	37.5	3.2
SZ036-042	H	10.5	18.1	40.1	3.2
	V	10.5	18.1	40.1	3.2
SZ048-060	H	10.5	18.1	42.4	3.2
	V	10.5	18.1	42.4	3.2

Shipping Dimensions and Water Connections (cm)

Model	Cabinet Config	Shipping Dimensions			Water Connections										Condensate Drain Pan		
		Depth/Length	Width	Height	Water In		Water Out		Water In/Out		HWG In		HWG Out		AA	BB	Condensate Drain Pan Fitting ³
		A	B	C	D	E	F	E	Com ¹	Res ²	DD	EE	FF	EE			
SZ024-030	H	135.9	72.1	61.6	9.5	5.1	24.8	5.1	3/4"	1"	33.3	4.0	40.2	4.0	8.6	2.1	3/4" MPT
	V	69.2	69.2	116.8	9.5	5.1	24.8	5.1	3/4"	1"	33.3	4.0	40.2	4.0	3.7	50.1	3/4" MPT
SZ036-042	H	148.6	72.1	68.6	9.5	5.1	28.1	5.1	3/4"	1"	37.7	4.0	44.7	4.0	8.6	2.1	3/4" MPT
	V	78.7	71.1	129.5	9.5	5.1	28.1	5.1	3/4"	1"	37.7	4.0	44.7	4.0	3.7	52.5	3/4" MPT
SZ048-060	H	189.2	79.7	68.6	9.5	5.1	28.1	5.1	1"	1"	40.0	4.0	47.0	4.0	8.6	2.1	3/4" MPT
	V	91.4	78.7	143.5	9.5	5.1	28.1	5.1	1"	1"	40.0	4.0	47.0	4.0	3.7	56.4	3/4" MPT

Notes:

- Commercial water connections are Female Pipe Thread (FPT) fittings
- Residential water connections are 1-inch swivel connections
- See PDF drawings for reference

Discharge and Return Connections (cm)

Model	Cabinet Config	Discharge Connection Duct Flange Installed				Return Connection Using Return Air Opening			
		Supply Height	Supply Width	O	P	Return Width	Return Height	S	T
		M	N			Q	R		
SZ024-030	H	33.3	24.5	10.0	3.0	58.3	41.3	3.1	2.5
	V	35.6	35.5	19.0	10.7	46.7	46.3	4.4	2.5
SZ036-042	H	40.6	27.9	7.4	6.4	66.2	48.3	3.0	2.5
	V	35.6	35.5	19.0	15.3	58.2	56.5	2.1	2.5
SZ048	H	40.4	34.4	10.3	3.0	91.6	48.3	3.0	2.5
	V	45.7	40.6	21.5	14.4	66.5	66.7	2.1	2.5
SZ060	H	45.8	33.9	10.6	2.9	91.6	48.3	3.0	2.5
	V	45.7	40.6	21.5	14.4	66.5	66.7	2.1	2.5

Hanger Dimensions (cm)

Model	Cabinet Config	Unit Hanger Detail		
		U	V	W
SZ024-030	H	122.3	62.4	51.5
SZ036-042	H	134.7	62.4	51.6
SZ048-060	H	172.2	70.0	59.2

ClimateMaster works continually to improve its products. As a result, the design and specifications of each product at the time of order may be changed without notice and may not be as described herein. Please contact ClimateMaster's Customer Service Department at 800-299-9747 for specific information on the current design and specifications. Statements and other information contained herein are not express warranties and do not form the basis of any bargain between the parties, but are merely ClimateMaster's opinion or commendation of its products. The latest version of this document is available at www.climatemaster.com. Engineered and assembled in the USA. © ClimateMaster, Inc. All Rights Reserved 2024

Electric Heater Knockouts

Models:
SZ
024-060

Electric Heater Knockouts (inch)

Model	Cabinet Config	X	Y
SZ024	H	1.5	5.1
	V	1.7	2.7
SZ030	H	1.5	5.1
	V	1.7	2.7
SZ036	H	1.1	6.3
	V	1.7	2.7
SZ042	H	1.1	6.3
	V	1.7	2.7
SZ048	H	1.5	6.3
	V	2.3	3.3
SZ060	H	1.5	6.3
	V	2.3	3.3

Electric Heater Knockouts (cm)

Model	Cabinet Config	X	Y
SZ024	H	3.8	13.0
	V	4.2	6.8
SZ030	H	3.8	13.0
	V	4.2	6.8
SZ036	H	2.9	15.9
	V	4.2	6.8
SZ042	H	2.9	15.9
	V	4.2	6.8
SZ048	H	3.8	15.9
	V	5.8	8.4
SZ060	H	3.8	15.9
	V	5.8	8.4

Corner Weights (lb)

Model	Left - Front	Right - Front	Left - Back	Right - Back
SZ024	68.0	56.0	42.0	42.0
SZ030	68.0	56.0	42.0	42.0
SZ036	76.0	63.0	47.0	47.0
SZ042	80.0	66.0	49.0	49.0
SZ048	98.0	81.0	60.0	60.0
SZ060	103.0	85.0	63.0	63.0

Corner Weights (kg)

Model	Left - Front	Right - Front	Left - Back	Right - Back
SZ024	30.8	25.4	19.1	19.1
SZ030	30.8	25.4	19.1	19.1
SZ036	34.5	28.6	21.3	21.3
SZ042	36.3	29.9	22.2	22.2
SZ048	44.5	36.7	27.2	27.2
SZ060	46.7	38.6	28.6	28.6

Minimum Installation Area

Models:
SZ
024-060

MINIMUM INSTALLATION AREA

Minimum area where a blower-equipped unit must be installed, and mechanical/natural ventilation is not required

Model	Charge (oz)	Configuration	Minimum Installation Area ft ² (m ²) [A _{min}]			
			Floor	Window	Wall	Ceiling
SZ060	69	Vertical	237 (22.0)	132 (12.2)	76 (7.0)	63 (5.9)
		Horizontal	237 (22.0)	141 (13.1)	79 (7.3)	65 (6.0)

A _{min} =	Minimum area where unit is installed where unit has incorporated airflow
h _{inst} (floor) =	0.0 ft (0.0 m)
h _{inst} (window) =	3.3 ft (1.0 m)
h _{inst} (wall) =	5.9 ft (1.8 m)
h _{inst} (ceiling) =	7.2 ft (2.2 m)

Minimum area and CFM requirements for the conditioned space

Model	Charge (oz)	Minimum CFM [Q _{min}]	
		TA _{min} (ft ²)	Q _{min} (ft ³ /min)
SZ060	69	3.54	117

TA _{min} =	Minimum conditioned area for venting leaked refrigerant
Q _{min} =	Minimum ventilation flow rate for conditioned space if space is less than TA _{min}

Minimum area of opening for natural ventilation

Model	Charge (oz)	Anv _{min} in ² (cm ²)
SZ060	69	111.57 (719.80)

Anv _{min} =	Minimum natural ventilation area opening
----------------------	--

When the openings for connected rooms or natural ventilation are required, the following conditions shall be applied:

- The area of any openings above 11.8 inches (300 mm) from the floor shall not be considered in determining compliance with Anv_{min}.
- At least 50% of the required opening area Anv_{min} shall be below 7.8 inches (200 mm) from the floor.
- The bottom of the lowest openings shall not be higher than the point of release when the unit is installed and not more than 3.9 inches (100 mm) from the floor.
- Openings are permanent openings which cannot be closed.
- For openings extending to the floor, the height shall not be less than 0.78 inch (20 mm) above the surface of the floor covering.
- A second higher opening shall be provided. The total size of the second opening shall not be less than 50% of minimum opening area for Anv_{min} and shall be at least 3.3 ft (1.5 m) above the floor.

ACCESSORIES AND OPTIONS

Hot Water Generator

An optional insulated heat reclaiming desuperheater coil of vented double-wall copper construction suitable for potable water shall be provided. The coil, hot water circulating pump, and associated controls shall be factory mounted inside the unit cabinet. Sensors mounted on the compressor discharge line and the potable water inlet shall transmit temperatures to the unit microprocessor where internal logic will determine when hot water generation is feasible. The microprocessor shall cycle the pump periodically during unit operation to sample the DHW tank temperature. The microprocessor shall include multiple temperature set points to select from for hot water generation control.

Cupro-Nickel Heat Exchanger

An optional corrosion resistant CuNi coaxial heat exchanger shall be factory installed in lieu of standard copper construction.

Thermostat (field installed)

An electronic communicating LCD thermostat shall be provided. The thermostat shall offer three stages of heating and two stages of cooling with precise temperature control and have a four-wire connection to the unit. The thermostat shall be capable of manual or automatic change-over operation and shall operate in standard or programmable mode. An integrated humidity control feature shall be included to control a humidifier and/or a dehumidifier. The thermostat shall include a utility demand reduction feature to be initiated by an independent time program or an external input.

The thermostat shall have a comprehensive installation setup menu to include configuration of the unit CFM for each mode of operation and configuration of the water flow rate through the unit, including variation of the water flow rate based on the stage of unit operation.

The thermostat shall display system faults with probable cause and troubleshooting guidance. Comprehensive service diagnostics menus shall display, system inputs, system outputs, configuration settings, Geo source inlet and outlet temperatures, compressor discharge line temperature, liquid line temperature, leaving air temperature, and entering potable water temperature (on units equipped with a Hot Water Generator). The thermostat shall allow for immediate manual control of all DXM2.5 outputs at the thermostat for rapid troubleshooting.

Auxiliary Heater (field installed)

An external, field-installed electric heater shall provide supplemental and/or emergency heating capability when used with the three stage heating thermostat.

The Optional Extended Factory Service Labor Allowance Warranty offers additional length of term protection to the consumer by offsetting service labor costs for 10 years.

To order this warranty, contact your ClimateMaster distributor. This coverage must be purchased within 90 days of unit installation. See Limited Express Extended Labor Warranty Certificate RP852 for details.



Revision History

Models:
SZ
024-060

Date	Section	Description
05/02/25	Model Nomenclature	Updated notes
	iGate 2 Smart tank	Added new accessory, iGate 2 Smart tank with accompanying information
	Electrical Data: CV EC	Updated data
	Dimensional Data	Added unique data for Size 048 Discharge and Return Connections dimensions
02/21/25	Performance Data	Added a note concerning Hot Water Generator Capacity calculation
	Electrical Data: CV EC Blower Motor	Updated Voltage Code for size 060
	Part Load Performance: Correction Tables	Updated correction data for Cooling, Entering Air Heating, and Airflow
	Full Load Performance: Correction Tables	Updated correction data for Cooling, Entering Air Heating, and Airflow
	Dimensional Data	Added shipping dimensions
	All	Added the Wireless Service Tool
	All	Updated the document's section order
01/28/25	Model Nomenclature	Updated footnote numbering
	Minimum Installation Area	Updated metric data
	Electrical Data: CV EC Blower Motor	Updated data
11/25/24	All	Updated naming conventions for DXM2.5 and AWC Thermostat
	Model Nomenclature	Updated Footnote references, Updated Model Nomenclature Updated Voltage and Water/Heat Exchanger options
	Performance Data	Clarified temperature ranges of performance notes, Updated Data
	Physical Data	Updated representation of HWG weight, Updated Unit Maximum Water Working Pressure
	Blower Performance Data	Updated data
	Minimum Installation Area	Updated Minimum Installation Area data
	Electrical Data	Added electrical data for the Standard unit with HWG
07/11/24	All	First Published



A NIBE GROUP MEMBER

7300 SW 44th St | Oklahoma City, OK 73179

Phone: 800.299.9747

www.climatemaster.com



R P 3 0 0 0

ClimateMaster works continually to improve its products. As a result, the design and specifications of each product at the time of order may be changed without notice and may not be as described herein. Please contact ClimateMaster's Customer Service Department at 800-299-9747 for specific information on the current design and specifications. Statements and other information contained herein are not express warranties and do not form the basis of any bargain between the parties, but are merely ClimateMaster's opinion or commendation of its products. The latest version of this document is available at www.climatemaster.com. Engineered and assembled in the USA. © ClimateMaster, Inc. All Rights Reserved 2024